



Conditions of Service

July 2026

Table of Contents

1	INTRODUCTION	1
1.1	Identification of Distributor and Service Area.....	1
1.2	Related Codes and Governing Laws.....	1
1.3	Interpretation.....	2
1.4	Amendments and Changes.....	2
1.5	Contact Information.....	2
1.6	Customer Rights	2
1.7	Distributor's Rights	3
1.8	Disputes.....	3
2	DISTRIBUTION ACTIVITIES (GENERAL)	5
2.1	Connections.....	5
2.1.1	Building That Lies Along.....	5
2.1.2	Expansions / Offer to Connect.....	5
2.1.2.1	Rationale.....	5
2.1.2.2	Definitions	6
2.1.2.3	Process.....	6
2.1.2.4	Connection Costs.....	6
2.1.2.5	Additional/Unforecasted Load	6
2.1.2.6	Phased Developments	7
2.1.2.7	Examples	7
2.1.3	Connection Denial.....	7
2.1.4	Inspections Before Connection.....	8
2.1.4.1	Overlap of Electrical Services.....	9
2.1.5	Relocation of Plant.....	9
2.1.6	Easements and Access to Equipment.....	10
2.1.7	Contracts	11
2.1.7.1	Payment by Building Owner	11
2.1.8	Customers with Dual Feeds	11
2.1.8.1	Customer Load Greater than 10 MW.....	11
2.1.8.2	Dual Feed due to London Hydro Loop-through Design	12
2.1.8.3	Backup Supply	12
2.1.9	Pole Attachments.....	13
2.2	Disconnection	13
2.2.1	Collection of Arrears.....	14
2.2.2	Disconnection On Order Of Inspection Department.....	14
2.2.3	Disconnection and Reconnection of Private High-Voltage Lines and Substations for Maintenance 15	
2.2.3.1	Introduction	15
2.2.3.2	Procedure	15
2.2.4	Disconnection & Reconnection of Residential Meters And Service Cables	16
2.2.5	Electrical Disturbances.....	16
2.2.6	Energy Diversion.....	16
2.2.7	Hazardous Conditions.....	16
2.2.8	Reconnection After Six Months	17
2.2.9	Disconnection of Overlapped Services.....	17
2.2.10	Demolition Requirements	17

2.2.11	House Moving.....	17
2.2.12	Removal of Transformers Supplying Abandoned or Inactive Services	17
2.3	Conveyance of Electricity.....	18
2.3.1	Limitations on the Guaranty of Supply	18
2.3.2	Power Quality	18
2.3.2.1	Customer Response Process	18
2.3.3	Electrical Disturbances	19
2.3.4	Standard Voltage Offerings.....	20
2.3.5	Voltage Guidelines.....	21
2.3.6	Backup Generators and other Non-Grid Connected Generators or Sources	21
2.3.7	Electric Metering Details & Requirements	22
2.4	Tariffs and Charges	22
2.4.1	Service Connections and Miscellaneous Charges	22
2.4.1.1	Customers Switching to a Retailer	22
2.4.1.2	Payment of Connection Charges and Supply Deposits	22
2.4.2	Energy Supply	22
2.4.2.1	Standard Supply Service (SSS)	22
2.4.2.2	Retailer Supply	22
2.4.3	Deposits.....	23
2.4.3.1	Security Requirement – Residential Customers	23
2.4.3.2	Security Requirement – Non-Residential (Commercial) Customers	23
2.4.3.3	Waiver of Security Requirement	25
2.4.3.4	Return of Security	25
2.4.3.5	Security Requirement - Retailer Prudential	26
2.4.3.6	Interest on Security.....	26
2.4.3.7	Payment of Security.....	26
2.4.3.8	Other Charges	26
2.4.3.9	Collection Procedures.....	27
2.4.4	Billing.....	27
2.4.4.1	General.....	27
2.4.4.2	Miscellaneous Charges.....	27
2.4.4.3	Sundry Charges.....	28
2.4.4.4	Primary and Secondary Billing (Associated Billing or Deduct Billing)	28
2.4.4.5	Billing Responsibility	28
2.4.5	Payments and Late Payment Charges/Interest.....	29
2.4.5.1	General.....	29
2.4.5.2	Collection Procedures.....	29
2.4.5.3	Good Payment History.....	30
2.4.5.4	Discretion Clause.....	31
2.4.6	Customer Class Definition and Application of Rates	31
2.4.6.1	Annual Rate Class Review.....	31
2.4.6.2	Temporary Services.....	32
2.4.6.3	Retail Distribution Billing Determinants	33
2.4.6.4	Retail Transmission Billing Determinants	36
2.4.6.4.7	Generation (Energy Metered Customer <50 kW)	38
2.4.6.4.8	Generation (New >1,000 kW)	38
2.4.6.4.9	Generation (Combination of Existing and New > 1,000 kW)	39
2.4.7	Distribution Rates	39
2.4.8	Energy Rates	40
2.4.8.1	Energy Rates for Consumed Energy	40
2.4.8.2	Consumption of Energy by Generation Customer	40

2.4.8.3	Payments for Energy Received from Generation Customer	40
2.4.8.4	Payments for Energy Received from “net metered” Customers under O. Reg. 541/05 – Generation Customer	41
2.4.8.5	Payments for Energy Received from Community Net Metered Customers under O. Reg. 679/21 Community Net Metering Project	41
2.5	Customer Information.....	41
3	CUSTOMER SPECIFIC	41
3.1	Residential	41
3.1.1	Single-Family Residential - General	41
3.1.1.1	Early Consultation	42
3.1.1.2	Point of Demarcation.....	42
3.1.1.3	Servicing Details	43
3.1.1.4	Metering	45
3.1.2	Multi-Family Residential	45
3.1.2.1	Metering.....	46
3.1.3	Residential Subdivision Developments.....	46
3.2	General Service	46
3.2.1	Early Consultation.....	47
3.2.2	Point of Demarcation.....	47
3.2.2.1	Overhead Secondary Services.....	47
3.2.2.2	Underground Secondary Services.....	48
3.2.2.3	Service Lengths Greater than 100 metres	48
3.2.2.4	Customer-Owned Substations.....	49
3.2.2.5	Deviations	49
3.2.3	Supply of Transformation and Fuse Coordination.....	49
3.2.4	Short Circuit Capacity	50
3.2.5	Access and Easements.....	50
3.2.6	Servicing Details	50
3.2.6.1	Overhead Secondary Services.....	50
3.2.6.2	Underground Secondary Services.....	50
3.2.7	Metering.....	52
3.3	General Service (Above 50 kW).....	52
3.4	General Service (Above 1000 kW)	52
3.5	Embedded Generation	52
3.5.1	General Requirements	52
3.5.1.1	Interface Protection and Isolating Devices	52
3.5.1.2	Compliance	53
3.5.2	Micro Generation General Requirements (<10kW).....	54
3.5.2.1	Documentation.....	54
3.5.2.2	Disconnection of Embedded Generation Facility	54
3.5.3	General Technical Information Requirements (>10kW)	54
3.5.3.1	Documentation.....	54
3.5.3.2	Metering for Embedded Generation Facilities.....	54
3.5.3.3	Transformers.....	55
3.5.3.4	Maintenance Schedules	55
3.5.3.5	Reporting Requirements	56
3.5.3.6	Capital Contribution.....	56
3.5.3.7	Disconnection of Embedded Generation Facility	56
3.6	Embedded Market Participant	56

3.7	Embedded Distributor	57
3.8	Unmetered Connections	57
3.8.1	Street Lighting.....	57
3.8.2	Traffic Signals.....	58
3.8.3	Bus Shelters	59
3.8.4	Other Small Services	59
3.8.5	Updating Unmetered Load Data	59
3.8.6	Notification of Material Changes Affecting Unmetered Load Customers	60
4	GLOSSARY OF TERMS	61

APPENDICES

- A EI-28-R7 "Disconnection & Reconnection of Residential Meters and Service Cables"
- B EI-29-R14 "Low Voltage Electric Metering Requirements"
- C EI-4-R10 "Design and Interconnection Requirements for Customer-Owned Electric Power Substations"
- D EI-22-R9 "Guidelines for Supplying Interval-Style Revenue Metering Systems"
- E Approved Retail Rates
- F Distributor Specific Electric Vehicle Charging Connection Requirements

1 INTRODUCTION

1.1 Identification of Distributor and Service Area

London Hydro Inc. referred to herein as either London Hydro or the Distributor is a Corporation, incorporated under the laws of the Province of Ontario to distribute electricity.

London Hydro is licensed by the Ontario Energy Board (OEB) to supply electricity to its Customers as described in its Distribution Licence issued on March 26, 2003 by the OEB. Additionally, there are requirements imposed on London Hydro by the various codes referred to in the Licence and by the Electricity Act and the Ontario Energy Board Act.

London Hydro operates distribution facilities within its licenced territory as defined in its Distribution Licence, generally within the boundaries of the Municipality of the City of London.

London Hydro will normally provide one electrical service to each Customer's location at a nominal service voltage. For new or upgraded electrical services, the Customer or their representative shall make an application and shall consult with London Hydro concerning the availability of supply, the voltage of supply, service location, metering and other details as described in these Conditions of Service. These requirements are separate from and in addition to those of the Electrical Safety Authority. Customers may be required to pay capital contributions for the addition of new electrical services in accordance with the policies and procedures outlined elsewhere in this document.

1.2 Related Codes and Governing Laws

London Hydro's scope of operation is defined by:

1. Electricity Act, 1998
2. Ontario Energy Board Act, 1998
3. Electricity Pricing, Conservation and Supply Act, 2002
4. Ontario Energy Board Amendment Act (Electricity Pricing), 2003
5. Distribution Licence
6. Affiliate Relationships Code
7. Transmission System Code
8. Distribution System Code
9. Retail Settlements Code
10. Standard Supply Service Code

In the event of a conflict between this document and the Distribution Licence or regulatory Codes issued by the OEB, or the Electricity Act, and its regulations, the Distribution Licence and associated regulatory Codes shall prevail.

When planning and designing an electricity service, Customers and their agents must refer to all applicable provincial and Canadian electrical codes, and all other applicable federal, provincial, and municipal laws, regulations, codes and by-laws to also ensure compliance with their requirements. The work shall be conducted in accordance with the Occupational Health and Safety Act, the Regulations for Construction Projects and the IHSA's Electrical Utility Safety Rules.

1.3 Interpretation

Questions as to the interpretation or intent of any part of this document should be directed to London Hydro and London Hydro shall have the sole right to make such interpretation.

Headings and underlining are for convenience only and do not affect the interpretation of these Conditions of Service. Words referring to the singular include the plural and vice versa and words referring to a gender include any gender.

1.4 Amendments and Changes

London Hydro reserves the right to make changes to these Conditions of Service at any time. In the event of changes, a public notice shall be made in the form of either a notice in the local newspaper, or a notice on London Hydro's Website (www.londonhydro.com). Suggestions for revisions or improvement can be directed to London Hydro at (519) 661-5800, Ext. 4512.

The Customer is responsible for contacting London Hydro to ensure they have the latest version of these Conditions of Service.

1.5 Contact Information

London Hydro and its agents can be contacted 8:30am to 4:00pm Monday to Friday at (519) 661-5503 or by email at billingsupport@londonhydro.com.

For repairs and service or in event of an emergency outside of normal working hours, please call (519) 661-5555.

For New Services and Connections, contact London Hydro at (519) 661-4749 or by email at commercial@londonhydro.com.

The business offices and a department directory can be reached at (519) 661-5800.

London Hydro's mailing address is: P.O. Box 2700
111 Horton St.
London, ON
N6A 4H6

1.6 Customer Rights

All Customers shall have non-discriminatory access to London Hydro's distribution system and services in accordance with the terms of these Conditions of Service and the applicable Acts, Regulations and Codes.

A Customer shall only be liable to London Hydro and London Hydro shall only be liable to a Customer for any damages that arise directly out of the wilful misconduct or negligence of London Hydro in providing distribution services to the Customer, of the Customer in being connected to London Hydro's distribution

system, or of London Hydro or the Customer in meeting the respective obligations under this Conditions of Service, their licences, and any other applicable law.

Notwithstanding the above, neither London Hydro nor the Customer shall be liable under any circumstances whatsoever for any loss of profits or revenue, business interruption losses, loss of contract or loss of goodwill, or for any indirect, consequential, incidental or special damages, including but not limited to punitive or exemplary damages, whether any of the said liability, loss or damages arise in contract, tort, or otherwise.

A Customer or Embedded Generator shall indemnify and hold harmless London Hydro, its Directors, Officers, Employees and Agents from any claims made by any third parties in connection with the construction, installation or operation of a generator by or on behalf of the Customer or Embedded Generator.

The provisions of these Conditions of Service and any amendments made from time to time form part of any Contract made between a connected Customer, Retailer, or Generator, and London Hydro.

1.7 Distributor's Rights

The supply of electricity is conditional upon London Hydro being permitted and able to provide such a supply, obtaining the necessary apparatus and material, and constructing works to provide the service. Should London Hydro not be permitted to supply or not be able to do so, it is under no responsibility to the Customer.

The Customer is required to provide London Hydro with sufficient lead time in order to ensure the timely provision of supply to new and updated premises or the availability of adequate capacity for additional loads to be connected at existing premises. If special equipment is required or equipment delivery problems occur, then longer lead times may be necessary. The Customer will be notified of any extended lead times.

Customers will be required to pay the cost of repair or replacement of London Hydro's equipment that has been damaged or lost by the direct or indirect act or omission of the Customer or its agents.

Nothing contained in this document or in any contract for the supply of electricity by London Hydro shall prejudice or affect any rights, privileges, or power vested in London Hydro by law under any Act of the Legislature of Ontario or the Parliament of Canada, or any Regulations thereunder.

London Hydro assumes no risk and will not be liable for damages resulting from the presence of its equipment on the Customer's premises or approaches thereto, or action, omission or occurrence beyond its control, or negligence of any Persons over whom London Hydro has no control.

Unless they are an Employee or an agent of London Hydro, or other Person lawfully entitled to do so, no Person shall remove, replace, alter, repair, inspect or tamper with London Hydro's equipment.

Other rights respecting access to equipment, payment of arrears, etc. are covered elsewhere in this document.

1.8 Disputes

Customer Complaint/Dispute Resolution Policy

Purpose

This Policy pertains to managing those individuals who have complaints regarding the service and/or service agreements provided by London Hydro. London Hydro is not responsible for handling complaints directed to

retailers. Those customers may speak to their retailers. Subsequently, retailers may wish to discuss the issue with London Hydro if deemed necessary.

Policy Objectives

- Complaints should be assessed and dealt with effectively in the shortest time possible
- Record all complaints to improve future service and prevent recurring complaints
- Maintain customer satisfaction
- Ensure consistency and enable effective allocation of CS resources
- All customers are billed accurately and fairly
- London Hydro recovers all revenues owed to it

Retailer Dispute Procedure

- 1) Refer to OEB Retail Settlement Code Article 6-Dispute Resolution

Retailers may not dispute:

- hourly spot prices
- NSLS calculations
- other regulated charges

References

- Retail Settlement Code, Appendix C
- Retail Settlement Code, sections 2.7, 4.2, 9 and 12
- Electricity Distribution Handbook, chapters 9 and 11

Customer Dispute Procedure

- 1) London Hydro staff receives the complaint
- 2) Attempt to resolve the issue immediately
- 3) If unable to resolve the issue, the complaint is transferred to the supervisor or delegate
- 4) If the supervisor or delegate is unavailable, the staff member completes a call back form and informs the customer that London Hydro will contact them within 5 business days
- 5) If the supervisor or delegate cannot resolve the problem, the Escalated Call Process is followed whereby the complaint is directed to the Manager
- 6) The Manager attempts to resolve the issue however if unsuccessful, consults the appropriate department and/or the Department Vice President
- 7) If the issue is still outstanding after this time, the complaint is forwarded to the Vice President of the Department or designate
- 8) After considering all options a negotiation may occur to reach a resolution
- 9) Subject to the outcome of #8, London Hydro may proceed to make a final offer
- 10) If the customer disagrees with the proposed resolution they may opt to take the complaint to the Ontario Energy Board. This action would be initiated by the customer, not by London Hydro.

2 DISTRIBUTION ACTIVITIES (GENERAL)

2.1 Connections

This section includes information that is applicable to all Customer classes. Information applicable to specific Customer classes can be found in Section 3. London Hydro specific requirements for connecting Electric Vehicle Supply Equipment (EVSE) are outlined in Appendix F.

2.1.1 Building That Lies Along

London Hydro, as the Distributor, has an obligation to connect any building that “lies along” its distribution system as stated in Section 28 of the Electricity Act 1998.

A building “lies along” a distribution line if it is within the boundaries of London Hydro’s licenced service territory, can be connected to London Hydro’s distribution system without an Expansion or Enhancement, and meets the conditions of service outlined in this document.

Sections 2.3 and 3 outline the conditions under which London Hydro will provide service to Customers that “lie along” an existing distribution line. Customers that meet these conditions will not be denied service. Conditions for connection refusal are outlined in Section 2.1.3.

2.1.2 Expansions / Offer to Connect

2.1.2.1 Rationale

Extending the distribution system to connect new Customers requires a capital investment. The revenue generated by the new load may or may not offset the capital investment and on-going maintenance costs of the system expansion. If there is a shortfall between the anticipated revenue and the capital and maintenance costs, the Customer is required to make up the difference by paying a capital contribution (See OEB Distribution System Code Section 3.2 for a full discussion of this Net Present Value (NPV) calculation). The Distribution System Code is available on the OEB’s website at www.oeb.ca.

Due to the uncertainty of load projections and changing market conditions London Hydro requires an expansion deposit equal to 100% of the present value of the forecasted revenues to be paid by the Customer (as described in Section 3.2.20 of the Distribution System Code). London Hydro’s preference is to receive the expansion deposit in the form of a letter of credit (cash and/or a surety bond are also acceptable).

Essentially, the capital contribution and the expansion deposit together represent the value of the total estimated capital investment. Once the expansion work is complete, the actual costs for the capital investment will be known and London Hydro will write to the customer to adjust the values on record for the capital contribution and the expansion deposit if required. If the actual cost of the work was less than estimated, London Hydro will rebate the customer the difference and if the actual cost was more than estimated, the customer will be required to make up the shortfall. Correspondingly, the amount of the expansion deposit may need to be readjusted.

Once the facilities are energized, London Hydro will annually return a percentage of the expansion deposit for up to five years in proportion to the actual number of connections (for residential developments) or actual demand (for commercial and industrial developments) that materialized in that year.

For all projects where the customer elects to use the alternative bid process to construct the expanded facilities, London Hydro will retain an expansion deposit for warranty purposes. For projects constructed through the alternative bid process, a 10% deposit will be retained for a warranty period of two years. The

two year Warranty Period begins when the last forecasted connection in the expansion project materializes or at the end of the customer connection horizon (5 years) whichever is first (as described in Section 3.2.24 of the Distribution System Code). This portion of the deposit can be applied to any work associated with repairing the expansion facilities within the two year warranty period. London Hydro will return any remaining portion of this part of the expansion deposit at the end of the two year warranty period.

2.1.2.2 Definitions

To connect a building that does not “lie along” the distribution system, a system expansion is required. A system expansion is defined as being that part of the London Hydro distribution system that needs to be extended or reinforced to feed a new load or Customer, and in future, could be used to feed additional Customers. Normally, this includes the distribution plant (primary and secondary conductors, poles, transformers, etc) installed along City of London streets and roadways to service present and future load additions. It does not include that part of the system installed on private property for the exclusive use of the Customer(s) on that specific property. For example, the primary cable and transformation installed on private property to serve a specific Customer or group of Customers are considered connection assets (see Section 3) and are not considered a system expansion.

Note: Connection assets are not subject to the NPV calculation and therefore, no rebates apply.

2.1.2.3 Process

Customers requiring a system expansion must submit detailed plans and specifications to the Engineering Department well in advance of the anticipated project start date. At a minimum, the plans must show property lines, building outlines, roadways, curbs, sidewalks, deep services, and preferred location(s) for transformation and/or service entrance. The specifications must indicate if servicing will be overhead or underground, the required voltage, estimated kW peak by year for 5 years, and desired in-service date.

Within 60 days of receipt of all relevant information, London Hydro will present the Customer with a written “Offer to Connect”. This Offer will contain an estimated cost to connect the service, including all applicable expansion costs that need to be immediately spent to expand the system to meet the Customers’ load requirement. A tentative schedule for installation and energization will be provided, subject to receipt of the estimated capital contribution, expansion deposit and schedule for completion of other deep services. The projected rebate, if any, will be estimated by London Hydro and written in the Offer to Connect. The estimated capital contribution must be paid by certified cheque. Both the capital contribution and the expansion deposit amount will be identified and must be paid in accordance with the Offer to Connect letter.

London Hydro will provide one free estimate and Offer to Connect for any new project. If owners or contractors wish to explore alternative scenarios for servicing, London Hydro can provide additional estimates on a time and material cost recovery basis.

2.1.2.4 Connection Costs

All connection charges are based on an overall cost recovery objective of one hundred percent (100%). For quotes on new services and connections, please refer to the contact information in Section 1.5.

2.1.2.5 Additional/Unforecasted Load

Within the first five years, if new Customers not included in the original development plan connect to the system expansion, the original Customer may be entitled to an additional rebate. New Customers connecting to the expanded facilities will be charged a proportional share of the original cost of the expanded facilities based on their load and location, and the original Customer will be entitled to a rebate. At 12 month intervals,

the original Customer may request London Hydro to review the NPV calculation if additional Customers have been added. No rebates will be issued for additional load added after five years from the day the system was energized.

2.1.2.6 Phased Developments

If a development will be constructed in phases over several years, the estimated cost of servicing the first phase may reflect costs associated with the installation of equipment to accommodate the future phases. Customers must clearly identify the timing and scope of future phases with their original submittal. In the "Offer to Connect", London Hydro will identify any costs associated with accommodating future phases in the servicing cost estimate.

2.1.2.7 Examples

The following examples will illustrate the above mentioned definitions and procedures.

i) Connection versus Expansion – Example #1

A new commercial plaza is to be built in an area where a three phase line is already in service along the street. The plaza requires an 800 A, 347/600 V three phase service, underground distribution with the transformer located at the side of the building. London Hydro prepares an Offer to Connect with a cost estimate for the three phase primary riser, underground primary cables, and a padmount transformer. These components are considered connection assets since they will provide service to the commercial plaza only. No rebates are applicable.

ii) Connection versus Expansion – Example #2

A new residential home is to be built on an acreage outside the core area of the City. The existing London Hydro distribution system stops 600m from the property line. The home requires a 200 A, 120/240 V single phase service, with overhead construction. The home will be built 200m back from the edge of the road. London Hydro prepares an Offer to Connect with a cost estimate for the following: 600m of single phase primary overhead distribution along the roadway, 200m of single phase primary overhead distribution on private property including a drop service (transformation and up to 30m of secondary at no charge). The 600m of distribution along the roadway are considered a system expansion since additional Customers could be added if more lots develop. The ownership of the 200m distribution line will be as per section 3.1.1.3. The NPV calculation is completed for the 600m section only. If additional Customers make use of this section within the next five years, the NPV calculation will be reviewed (see next example).

iii) Additional Customers – Example #3

Two years after the line extension in the previous example has been in service, a nearby landowner decides to develop a property. The point of connection is at the mid-point of the expansion which was paid for by the original Customer. London Hydro prepares an Offer to Connect for the new Customer which includes 25% of the actual cost to build the 600m extension (50% of the cost to build the shared portion of the line extension). After the new Customer has been connected, the original Customer asks to have the NPV calculation reviewed. With the additional load added and the money collected for the shared portion of the line extension, the NPV calculation reveals the original owner is entitled to an additional rebate.

2.1.3 Connection Denial

London Hydro has the right to refuse to connect, or continue to connect, a Customer for any of the following reasons as specified in the Distribution System Code:

- Contravention of the laws of Canada or the Province of Ontario.
- Violation of conditions in London Hydro's Distributor's Licence.
- Use of a distribution system line for a purpose that it does not serve and that London Hydro does not intend it to serve. (e.g., using a pole to mount a sign or as a support for a fence, etc.)
- Adverse effect on the reliability or safety of the distribution system.
- Imposition of an unsafe work situation beyond normal risks inherent in the operation of the distribution system.
- A material decrease in the efficiency of London Hydro's distribution system.
- A materially adverse effect on the quality of distribution services received by an existing connection.
- Discriminatory access to distribution services.
- If the person or business requesting the connection, or an associated business owes London Hydro money for distribution services, including security deposits or capital contributions
- If an electrical connection to London Hydro's distribution system does not meet London Hydro's design requirements.
- Violation of any other conditions in this Conditions of Service document.

If London Hydro refuses to connect a building or facility that lies along one of its distribution lines, London Hydro will inform the person requesting the connection of the reasons for not connecting, and where London Hydro is able to provide a remedy, will make an offer to connect. If London Hydro is unable to provide a remedy to resolve the issue, it is the responsibility of the Customer to do so before a connection may be made.

2.1.4 Inspections Before Connection

All Customer electrical installations shall be inspected and approved by the Electrical Safety Authority and must also meet London Hydro's requirements. London Hydro requires notification from the Electrical Safety Authority of this approval prior to the energization of a Customer's supply of electricity. Services that have been disconnected for a period of six months or longer due to non-payment must also be re-inspected and approved by the Electrical Safety Authority prior to reconnection. Any service disconnected for any other reason requires re-inspection by the Electric Safety Authority (Electrical Safety Code Rule 2-012.).

In the event the Customer's existing service mast is damaged (for example, during a storm), the Customer is responsible for re-installing and re-anchoring the service mast and the installation must be re-inspected and approved by the Electrical Safety Authority before London Hydro can re-install the service conductors.

Temporary services, typically used for construction purposes, must be approved by the Electrical Safety Authority for a period of twelve months and must be re-inspected should the period of use exceed twelve months.

London Hydro reserves the right to inspect and witness the construction of any equipment or facilities that will be connected to London Hydro's distribution system. London Hydro will notify the Customer in advance if any witness testing or inspections will be required during construction.

All electrical equipment and materials used by the Customer will be subject to approval by London Hydro, the Electrical Safety Authority and the Canadian Standards Association (CSA) failing which, London Hydro reserves the right to withhold connection to the supply.

2.1.4.1 Overlap of Electrical Services

In certain situations where an existing service is being upgraded or relocated, London Hydro may allow two services to be energized for a period of up to 15 days to provide the owner with adequate time to transfer all internal circuits to the new system.

Prior to any overlap of services, the owner must obtain approval from London Hydro's Engineering Department and London Hydro reserves the right to disconnect the non-permanent service should the 15 day overlap period be exceeded.

2.1.5 Relocation of Plant

Anyone other than a Road Authority requesting London Hydro to relocate its plant or equipment will be required to pay 100% of the costs incurred by London Hydro. The above costs would include all engineering, labour, material, equipment, trucking, easements, applicable burdens, administrative costs, and taxes associated with the required plant modifications.

An exception to the 100% recovery of costs would occur in cases where London Hydro decided to modify or enhance its distribution system for its own purposes and did not replace or relocate the equipment in a "like for like" manner. Relocating plant "like for like" is defined as new plant built to the latest London Hydro standards that has the capacity to perform the same function as the plant that it replaces. In those cases, where the equipment is not relocated in a "like for like" manner, the differential in cost will be absorbed by London Hydro.

Anyone requesting the relocation of London Hydro's plant or equipment must submit a written request to London Hydro in order to initiate the relocation process. London Hydro will provide a cost estimate and must receive either a certified cheque in advance or a Letter of Guarantee from a chartered bank prior to any work being done.

If the relocation is from public to private property or is within the requestor's private properties, then the requestor must supply London Hydro with equivalent property rights in the form of a new easement, tree cutting rights, etc. if applicable.

The requestor is responsible for siting the new locations of all plant to be relocated as agreed to by London Hydro. The costs for any subsequent relocations required due to improper siting will be at the expense of the person requesting the locate.

If a Customer installs a new driveway and London Hydro's overhead structure does not have adequate clearance because of the location of the new driveway, London Hydro will raise or relocate its plant at no cost to the Customer. Where a Customer requires an aerial service to be relocated because of a proposed addition or swimming pool, the Customer will be responsible for 100% of the costs incurred. London Hydro will normally relocate and attach the service to the most secure point along the distribution system where

feasible. Normally an aerial service will be relocated to the property line between two neighbouring Customers to avoid further relocation.

Should a Customer require relocation of an underground service cable and/or a high voltage primary cable to clear a proposed addition or swimming pool, the Customer is required to provide a new trench between London Hydro's distribution point and the point of connection at the Customer's meter stack. London Hydro must be consulted to determine the location of the distribution point. The Customer will be responsible for 100% of the costs incurred.

2.1.6 Easements and Access to Equipment

The Customer shall grant, at no cost to London Hydro, where requested, an easement to permit the installation and maintenance of service. The width and extent of this easement shall be determined by London Hydro. In the case of multi-dwelling units such as townhomes or condominiums, a blanket easement on the entire property shall be provided to London Hydro by the Customer. The easement shall be granted prior to installation of the service.

To maintain the reliability, structural integrity and efficiency of the distribution system, London Hydro has the right to have supply facilities on private property registered against title to the property. Easements are required whenever London Hydro's underground or overhead plant is to be located on or above private property and crosses over to an adjacent property to service a Customer other than the owner of the original property. An easement may also be required if a property will be severed or if service locations require London Hydro to gain access from adjacent properties (e.g. mutual driveways, narrow side setbacks, land locked properties, etc.).

London Hydro's Engineering Design department must be contacted in situations where a severance results in the new parcels being supplied and metered through a common service. This is necessary in order to ensure that customers on the resultant parcels are adequately supplied and metered in accordance with industry regulations.

The Customer will prepare, at their own cost, a reference plan and associated easement document(s) to the satisfaction of London Hydro's solicitor prior to its registration and will register the easement plan. Details will be provided upon application for service.

London Hydro requires access to a Customer's premises at all reasonable times to read meters, or to inspect, repair, or remove meters, wires, cables, or equipment owned by London Hydro. Customers must also provide sufficient access and clearance to permit London Hydro to adequately service its equipment including padmounted transformers, switching units, vaults, meters, etc.

For padmounted equipment, each side of the concrete pad must have at least 1 metre of clearance except any side with an access door which must have 2.5 metres of clearance in front. A clear path must be available to provide access to the equipment. No landscaping, bushes, sheds, or equipment should encroach on this area. Concrete pads must remain at least 5 cm above the surrounding grade and the grade of the immediate area should be sloped in such a manner that water does not collect around the pad.

London Hydro is not responsible for any damage or removal of any Customer-owned landscaping or equipment within the access area or on the easement. Where London Hydro is required to perform surface restoration following any repairs or maintenance to a Customer's service, London Hydro will provide only soil, sod, gravel or asphalt repairs.

Where a customer owns a private structure that impedes access to their own underground secondary service cable (eg. a shed, deck, concrete pad, landscaping, etc.), they will be responsible for all costs to remove the obstruction or relocate the service cable in the event repairs need to be made. London Hydro reserves the right to leave the premises without power until a remedy has been agreed to.

Where a Customer's service entrance is located more than 100m from the right-of-way and the Customer has elected to transfer the ownership and future maintenance of the primary line to London Hydro, the Customer will be responsible for maintaining and clearing an all weather roadway for vehicle access along the length of line.

2.1.7 Contracts

Generators and Customers with Customer-owned substations will be required to sign a Connection Agreement prior to commencement of service. London Hydro may require, at its discretion, other Customers with unusual conditions to also sign a Connection Agreement. In addition to contracting for the conveyance of electricity and the use of London Hydro's distribution system, Connection Agreements will typically define boundaries and responsibilities for the ownership, operation and maintenance of equipment at the Customer's location.

In all cases, notwithstanding the absence of a formal contract, or Connection Agreement, the taking and using of electrical energy from London Hydro by any Person or Persons implies and constitutes the acceptance of the terms and conditions of all regulations and rates as established by London Hydro. Such acceptance and use of energy shall be deemed to be the acceptance of a binding contract with London Hydro and the Person so accepting shall be liable for payment for all services and energy received and the contract shall be binding upon the Person's heirs, administrators, executors, successors or assigns.

2.1.7.1 Payment by Building Owner

The Owner of a building is responsible for paying for the supply of electricity by London Hydro to the building except in the case of multi-tenant buildings with individual meters where the occupants have contracted for supply with London Hydro. In the case of multi-tenant buildings with bulk metering, the Owner must pay the total cost of the electrical account. The Owner may then apportion the bill among individual tenants through inclusion in rent or contract a licenced unit sub-metering provider.

A Building Owner wishing to terminate the supply of electricity to their building must notify London Hydro in writing. Until London Hydro receives such written notice from the Owner, the Building Owner or the Occupant(s), as applicable, shall be responsible for paying for the supply of electricity to the building. London Hydro reserves the right to refuse to terminate the supply of electricity to an Owner's building when there are occupant(s) in the building (e.g. during certain periods of the winter). If billing responsibility resides with the owner and there is a unit occupied by a tenant, the Vital Service By-Law of the City of London will be enforced.

2.1.8 Customers with Dual Feeds

There are a number of different circumstances under which a Customer may require or request two sources of primary supply and/or two high voltage connections. Various situations are described below:

2.1.8.1 Customer Load Greater than 10 MW

For operational flexibility and power quality considerations on the grid, the largest load that can be fed by a single primary supply at 16/27.6Y kV is 10 MW.

If a Customer's load is predicted to exceed 10 MW then a second primary supply must be provided. The Customer will be permitted to totalize the load fed from the two supplies for peak demand metering purposes and will be responsible for paying the connection charges for both sources of supply as described in Section 3.

If a Customer requires two primary connections because of load reasons, normal design practice would suggest that if possible, the two connections should also come from two separate sources of supply. This may not always be possible without a system expansion. If for security purposes, a Customer requires their two connections to be fed from separate sources of supply and if a system expansion is required to provide this, the Customer will be responsible for contributing to the cost of the expansion as outlined in Section 2.1.2.

2.1.8.2 Dual Feed due to London Hydro Loop-through Design

At times, the design of London Hydro's distribution system will call for a loop-through design that results in a Customer having two high voltage connections.

In the case of a loop-through padmount transformer for example, if London Hydro has chosen to put the Customer's transformer on a loop to enable the circuit to continue to feed other Customers, the first Customer receives the benefit of two high voltage connections at no extra charge.

In a case where a Customer owns their own switchgear and substation, if London Hydro chooses to add another cell to the switchgear to permit the primary circuit to continue to feed other Customers, London Hydro will pay for the cost of the additional switchgear cell. London Hydro could also elect to provide a separate switching unit with a tap to the Customer's equipment to allow for the loop through design. The Customer would therefore benefit from having two high voltage connections at no extra cost.

In these situations, it will be solely at London Hydro's judgement whether or not a loop-through circuit is required to allow the servicing of additional Customers.

2.1.8.3 Backup Supply

Customers who have two high voltage connections must also decide how much transfer capability they require internally between the two connections and whether or not they require a true second source of supply.

As discussed earlier, normal design practice would attempt to connect a Customer's two high voltage connections to two separate feeders if such feeders were available. However, there is no guarantee in the future that those two feeders will actually remain as separate feeders. As loads change and as work on London Hydro's system progresses, switching of the system could result in both high voltage connections being actually fed from the same feeder. In some cases, a long term review of the distribution system in the area could result in such a situation becoming permanent. Therefore, if a Customer requires a true second source of supply, this must be identified during the planning stages, and arrangements must be made to ensure that the second high voltage connection will always be fed from a second source.

London Hydro also has restrictions on how much load can be transferred between feeders. If a Customer has an open-transition (i.e. break-before-make) auto or manual transfer capability within their premises, London Hydro will permit the Customer to transfer up to one megawatt (1 MW) of load (at 27.6 kV) from one high voltage connection to the other at any time without charge. There are restrictions on transferring embedded generation and/or distributed energy resources (DERs) – contact London Hydro for details.

If the Customer wishes to be able to transfer more than one megawatt (1MW) between its two high voltage connections, they will need to notify London Hydro of their desire and request permission to make the load transfer. While London Hydro will strive to accommodate these requests, London Hydro reserves the right to

deny the transfer because of loading conditions or system configuration at the time, The Customer must be prepared to accept that their request to transfer load can be denied by London Hydro at any time since there would be no special planning guidelines in place to ensure that the customer has reserved capacity available on the second source of supply.

Also see Section 2.3.5 for a further discussion of billing arrangements for customers with more than one metered service connection.

2.1.9 Pole Attachments

Customers will not be permitted to make any attachments to London Hydro's poles without written consent. Generally, consent will only be provided to the City of London and City of London licenced franchisees. Each pole attachment is subject to a yearly joint use charge (contact the Engineering Dept. for the latest approved rate) and the use of London Hydro's poles for Customer-owned service cables or equipment will only be permitted under special circumstances.

Unacceptable attachments include privately owned electrical service equipment and lighting, private signs, banners and notices, and privately owned brackets and planters. Any such attachments not approved by London Hydro will be removed at the owner's expense.

Notwithstanding this policy, London Hydro will cooperate with community groups to allow the use of London Hydro poles for certain community purposes. In all cases the design of the attachment must meet strict requirements to minimize wind loading and damage to the pole and all such installations must have full approval by the City of London who controls the use of the right-of-way. All costs and liability for the attachments are the responsibility of the community group.

2.2 Disconnection

London Hydro reserves the right to disconnect the supply of electrical energy for causes not limited to:

- Contravention of the laws of Canada or the Province of Ontario.
- Adverse effect on the reliability and safety of the distribution system.
- Imposition of an unsafe worker situation beyond normal risks inherent in the operation of the distribution system.
- A material decrease in the efficiency of the Distributor's distribution system.
- A materially adverse effect on the quality of distribution services received by an existing connection.
- Discriminatory access to distribution services.
- Inability of London Hydro to perform planned inspections and maintenance.
- Failure of the Customer to comply with a directive of London Hydro that London Hydro makes for purposes meeting its licence obligations.
- Failure of the Customer to maintain customer owned equipment that London Hydro believes poses a safety or system reliability risk.

- Overdue amounts owed by a Customer payable to London Hydro for the distribution or retail sale and supply of electricity.
- Electrical disturbance propagation caused by Customer equipment that is not corrected in a timely fashion.
- Energy diversion, fraud or abuse
- The Customer failing to provide a security deposit as required.
- Inability of London Hydro to access revenue meter data, or perform planned inspections, installations or maintenance of revenue metering equipment.
- Any other conditions identified in this Conditions of Service document.

London Hydro may disconnect the supply of electricity to a Customer without notice in accordance with a court order, or for emergency, safety, or system reliability reasons. The remainder of this section describes in more detail various disconnection circumstances.

2.2.1 Collection of Arrears

Immediately following the last due date for net payment, steps shall be taken to collect the full amount of the bill. If the bill is still unpaid six days after the last date for net payment, London Hydro may initiate a notification process that may result in the service being disconnected and not reconnected until satisfactory payment or payment arrangements have been made. Additional charges including reconnect charges, late payment charges and security deposits may be billed where applicable.

No Customer shall be disconnected without first having been issued a disconnection notice advising the Customer of the disconnection timeframe. If a Customer does not pay the minimum required amount, London Hydro may limit or turn off the supply of power.

Where applicable, London Hydro will provide Fire and Safety Notices to the affected Customer. In the event billings are being paid by owners in which tenants are involved, London Hydro will endeavour to notify the tenant in writing seven days in advance of its intention to disconnect the supply of power. This notice will only be utilized when all other attempts have failed. If billing responsibility resides with the owner and there is a unit occupied by a tenant, the Vital Service By-Law of the City of London will be enforced.

Disconnection is not the same as termination of the Customer's contract for service. Disconnection in this section does not relieve the Customer of the liability for arrears or monthly service charges for the balance of the term of contract nor shall London Hydro be liable for any resulting damage on the Customer's premises.

2.2.2 Disconnection On Order Of Inspection Department

The Electrical Safety Authority has the power under the Electricity Act, 1998 to order any utility to disconnect a service. The regulations pertaining to service discontinuance are contained in the Ontario Electrical Safety Code.

2.2.3 Disconnection and Reconnection of Private High-Voltage Lines and Substations for Maintenance

2.2.3.1 Introduction

Customers normally perform substation maintenance annually on the transformers and switchgear contained within the confines of their private substation, and occasional vegetation clearing in proximity to their private aerial high-voltage lines. When this occurs there are a number of procedures that should be followed before this maintenance can be completed.

2.2.3.2 Procedure

The steps to be followed by owners or electrical contractors are outlined below:

- i) The owner or electrical contractor will contact a London Hydro representative at (519) 661-5800 extension 5450 to arrange a date and time for the disconnection and reconnection of the high voltage connections for the substation. London Hydro normally requires at least ten (10) working days advanced notice to schedule the disconnection and reconnection of the substation.
- ii) The owner or electrical contractor will supply London Hydro with a purchase order number and a billing address.
- iii) It is the responsibility of the owner or electrical contractor to contact the Electrical Safety Authority and complete an "Application for Inspection", where applicable (not required if disconnections are only for vegetation maintenance).

It should be noted that London Hydro is unable to reconnect the supply power until connection authorization has been received from the Electrical Safety Authority. In order to improve the inspection efficiency, the Electrical Safety Authority has an "advanced connection authorization" program available to qualified contractors. In this case the contractor shall provide the Electrical Safety Authority with at least two working days advanced notification of scheduled work. Provided that a permit has been issued for the work, the Inspection department will issue an advanced connection authorization to London Hydro. The Inspection Department will perform the actual inspection following reconnection of the substation.

- iv) All substation disconnections and reconnections for maintenance are performed under a time and material basis. If the work is carried out during normal working hours (7:30 to 16:00) Monday to Friday except holidays, regular time will apply, any hours worked outside normal working hours will be billed at premium time.

The Electrical Safety Authority establishes the fee schedule for Electrical Inspections. Note that this fee schedule is revised annually.

- v) If the electrical contractor does not require London Hydro to disconnect the high voltage connections but only requires the T1-L switch for isolation, the contractor may open this switch provided that they use approved safety procedures and contact London Hydro's System Operating Centre at 661-5800 ext. 5585 before operating the switch. The operation of the switch by the electrical contractor is permissible because the switch is normally part of the private substation.
- vi) In the event that London Hydro is unable to perform scheduled work due to inclement weather, distribution system emergencies or similar, London Hydro's System Operating Centre will contact the owner or electrical contractor to reschedule the work.

If a maintenance job is scheduled to be completed during premium time and the owner or electrical contractor cancels the job within 24 hours of the start time, two hours at the applicable premium rate will be billed to the job.

2.2.4 Disconnection & Reconnection of Residential Meters And Service Cables

Appendix A contains London Hydro's Operating Instruction EI-28 which describes the procedure for disconnecting and later reconnecting meters and secondary supply service cables to residential buildings.

2.2.5 Electrical Disturbances

Customers must ensure that their equipment does not cause any disturbances such as harmonics and spikes that may interfere with the operation of adjacent Customer equipment. Examples of equipment that may cause disturbances include large motors, welders and variable speed drives.

If an undesirable system disturbance is being caused by the Customer's equipment, the Customer will be required to cease operation of the equipment until satisfactory remedial action has been taken. If the Customer does not take such action within a reasonable time, then London Hydro may disconnect the supply of power to the Customer.

When the supply of power is disconnected because of electrical disturbances, inspection is required before reconnection. It shall be the responsibility of the Customer requiring the reconnection to arrange for the inspection and the payment of fees.

London Hydro also reserves the right and has an obligation to disconnect a Customer's private line or equipment if it has caused or is likely to cause because of its condition, a disturbance or outage on London Hydro's system. It is the Customer's responsibility to maintain their privately owned equipment to industry accepted standards to ensure that outages affecting other London Hydro Customers do not occur due to lack of maintenance.

2.2.6 Energy Diversion

If London Hydro should find that energy diversion, fraud or abuse is taking place at a Customer's location, then London Hydro may disconnect the supply of power to the Customer.

When the supply of power is disconnected because of energy diversion, fraud or abuse, inspection is required before reconnection. It shall be the responsibility of the Customer requiring the reconnection to arrange for the inspection and the payment of fees.

2.2.7 Hazardous Conditions

If London Hydro should discover hazardous wiring or conditions that would put the life of the general public or London Hydro employees in jeopardy, the Customer will be notified of the condition and will be required to remedy the hazard. If the Customer does not take such action within a reasonable time, then London Hydro may disconnect the supply of power to the Customer.

When the supply of power is disconnected because of an electrical hazard, inspection is required before reconnection. It shall be the responsibility of the Customer requiring the reconnection to arrange for the inspection and the payment of fees.

2.2.8 Reconnection After Six Months

Where a service has been disconnected by London Hydro for non-payment of rates or because of a change in occupancy for longer than six months, reconnection will be subject to the connection-authorization requirements of Rule 2-012 of the Ontario Electrical Safety Code. The party requesting reconnection is responsible for arranging any required inspection or authorization through the Electrical Safety Authority and paying the applicable fees.

Where no active account has existed at a property for six months following closure of the previous customer account, London Hydro will make reasonable efforts to contact the property owner to determine whether electrical service is still required. If service is required, the property owner will be required to open an account. If service is not required, the property owner cannot be contacted, or an account is not opened, London Hydro may remove the transformer and associated equipment.

2.2.9 Disconnection of Overlapped Services

London Hydro reserves the right to disconnect a service in situations where 2 services have been permitted to be overlapped should the overlap period exceed 15 days. (See Section 2.1.4.1).

2.2.10 Demolition Requirements

Anyone requesting a building demolition must first obtain a City of London Demolition Permit Application. The City of London will request London Hydro to confirm the disconnection and removal of all hydro services and equipment. To avoid delays, the Applicant must provide the following information to London Hydro's Dispatch Office at 661-5555: correct demolition address, all London Hydro accounts and meter numbers associated with the property, the Customer's name and phone number, and the list of equipment to be removed.

2.2.11 House Moving

If the loaded height of a house or building that is going to be moved is over 4.42 metres (14.5 feet), application must be made to London Hydro before the building can be moved on City streets.

The mover is required to complete an application at the City Clerk's Office, City Hall, 300 Dufferin Avenue and provide this application to London Hydro. Following an on-site visit to view the building and the proposed route of the move, the Engineering Department will provide the mover with an estimated cost based on the loaded height of the building, the distance and the route that will be taken. The mover must guarantee the height of the building at the time of making the deposit.

London Hydro will disconnect or raise overhead wires during the move and the mover will be required to pay the actual costs incurred.

2.2.12 Removal of Transformers Supplying Abandoned or Inactive Services

Where London Hydro determines that no active customer accounts are associated with the services supplied by a transformer, or that the building supplied by the transformer has been abandoned, London Hydro will make reasonable efforts to contact the property owner to determine whether electrical service will be required in the future.

If the property owner confirms that electrical service is still required, the property owner will be required to open an account. If electrical service is not required, the property owner cannot be contacted, or an account is not opened, London Hydro may remove the transformer and associated equipment. Removal may occur at any time based on the available information but will normally be completed within six months after the previous customer account has been closed.

2.3 Conveyance of Electricity

2.3.1 Limitations on the Guaranty of Supply

London Hydro will endeavour to use reasonable diligence in providing a regular and uninterrupted supply but does not guarantee a constant supply or the maintenance of unvaried frequency or voltage and will not be liable in damages to the Customer by reason of any failure in respect thereof.

Customers requiring a higher degree of security than that of normal supply are responsible to provide their own back-up or standby facilities. Customers may require special protective equipment at their premises to minimize the effect of momentary power interruptions or voltage sags.

London Hydro will endeavour to maintain voltage variation limits under normal operating conditions at the Customers' delivery points as specified by the latest edition of the Canadian Standards Association, C235.

Customers requiring a three-phase supply should install protective apparatus to avoid damage to their equipment, which may be caused by the interruption of one phase, or non-simultaneous switching of phases of the power supply by London Hydro.

Although it is London Hydro's policy to minimize inconvenience to Customers, it is necessary to occasionally interrupt a Customer's supply to maintain or improve London Hydro's system or to provide new or upgraded services to other Customers.

When practical, London Hydro will endeavour to notify Customers prior to interrupting the supply of power to any individual service. However, if an unsafe or hazardous condition is found to exist or if the use of electricity by a Customer's apparatus, appliances or other equipment is found to be unsafe or damaging to London Hydro or the public, or if service must be disconnected to assist in the safe or efficient restoration of power, or maintenance of London Hydro's system, or in response to a shortage in supply, service may be disconnected without notice.

London Hydro shall have access rights to a property in accordance with Section 40 of the Electricity Act, 1998 and any successor Acts thereto.

2.3.2 Power Quality

London Hydro's electric distribution system is designed and operated to meet or exceed the Service Quality Performance Standards published by the OEB. When a customer has a concern about the operation of their electrical equipment related to transient or steady state voltage levels, flicker, harmonic distortion, farm stray (or tingle) voltage, etc., London Hydro will deal with the concerns as follows:

2.3.2.1 Customer Response Process

When customer Power Quality concerns are received, London Hydro will try to resolve the problem without having to make a site visit. If you suspect a problem at your property related to voltage levels, flicker, harmonic distortion, farm stray (or tingle) voltage please contact London Hydro at opsadmin@londonhydro.com. When the problem cannot be addressed or resolved over the phone, a site visit will be made to assess the concern. If the power quality problem cannot be easily identified during this site assessment, a power quality monitor

will be installed at the customer service entrance or stray voltage measurements will be made in accordance with Appendix H of the Distribution System Code. If the cause of the problem is identified as a London Hydro responsibility, London Hydro will take appropriate mitigation measures. If the problem is identified as being on the customer side of the system, the customer will be informed by a written report of the results of the analysis and their responsibility.

Any site assessment visit should occur within 10 business days of the initial call from the customer.

Should monitoring be required, it could take up to another 10 business days to identify the probable source of the power quality concern.

If the power quality issue is identified as a London Hydro controllable source, London Hydro will take mitigating action within 10 business days of the identification. Depending upon the source, it may take from 1 day to 60 days to resolve. In some cases, resolution may involve only the definition of a planned course of action.

If the power quality issue is identified as a customer responsibility, London Hydro will document the issue to the extent known in a written report to the customer within 10 business days of the identification. London Hydro may follow up to ensure that the customer has initiated an appropriate plan of action.

2.3.3 Electrical Disturbances

London Hydro shall not be held liable for the failure to maintain supply voltages within standard levels due to Force Majeure as defined in Section 2.3.5 of these Conditions of Service.

Voltage fluctuations and other disturbances can cause flickering lights and other serious difficulties for Customers connected to London Hydro's distribution system. Customers must ensure that their equipment does not cause disturbances such as harmonics or spikes that might interfere with the operation of adjacent Customer equipment. Equipment that may cause disturbances includes large motors, welders, variable speed drives, etc. In planning the installation of such equipment, the Customer must consult with London Hydro.

In general, larger motors will require reduced voltage starting equipment to prevent electrical disturbances. The largest motors permitted to be started across the line are as follows:

120/240 volts - 3 H.P.

120/208Y volts - 5 H.P.

347/600Y volts - 25 H.P.

Under certain conditions where the service entrance equipment rating is low in comparison to the motor starting inrush current, if lamp flicker becomes objectionable at an adjacent Customer's premises, reduced voltage starting equipment will be required on motors smaller than those specified above.

Customers having non-linear load shall not be connected to London Hydro's distribution system unless power quality is maintained by implementing proper corrective measures such as installing filters, and/or grounding. Further, to ensure the distribution system is not adversely affected, installed power electronics equipment must comply with IEEE Standard 519-Latest Edition. The limit on individual harmonic distortion is 3%, while the limit on total harmonic distortion is 5%.

Customers who may require an uninterrupted source of power supply or a supply completely free from fluctuation and disturbance, must provide their own power conditioning equipment for these purposes.

2.3.4 Standard Voltage Offerings

London Hydro distributes electrical power through a 27.6 kV primary distribution system. The legacy 13.8 kV system has been converted to 27.6 kV as part of London Hydro's long term system plans. All supply feeders are arranged to run radial with open points between interconnections where practical. These feeders supply distribution transformers either directly or through 4.16 kV or 8.32 kV step-down sub-distribution systems.

London Hydro also maintains an underground network system in the downtown core that is distinct from the other systems. This low voltage secondary network system may be available to some Customers in the downtown core as a source of supply at 120/208Y volts depending on the local capacity of the system and the energy requirements of the Customer. Spot networks might also be available.

The supply of electricity at primary voltage levels will primarily be at 27.6 kV depending on the proximity of the Customer's premises to the nearest distribution facility. For connection of a Customer at 4.16 kV, London Hydro will carry out a special study to justify the investment as in many areas the 4.16 kV distribution facilities are being phased out. The cost of this study may be charged to the Customer.

London Hydro's standard secondary supply voltages are as follows:

- 120/240 volt, single phase, 3 wire
- 120/208Y volt, three phase, 4 wire (grounded wye)
- 347/600Y volt, three phase, 4 wire (grounded wye)

Not all secondary voltages are available at all locations. For example, some areas only have single phase power available and other areas such as industrial subdivisions may have a standardized 347/600Y volt secondary bus. In all cases Customers are required to consult with London Hydro to determine what secondary voltages are available.

London Hydro also has the following primary voltages in some but not all parts of its service territory:

- 2.4/4.16Y kV, three phase, 4 wire (grounded wye)
- 4.8/8.32Y kV, three phase, 4 wire (grounded wye)
- 16.0/27.6Y kV, three phase, 4 wire (grounded wye)

As stated above, not all of these voltages are available in all areas of London Hydro's service territory. Customers are required to consult with London Hydro to determine what voltages are available and to discuss their service requirements.

Customers requiring different voltages than those available in their area will be required to provide their own step down or step up transformation equipment.

In general, only one service will be permitted per Customer at one voltage, i.e., the Customer must supply their own transformation if other voltages higher or lower than the service voltage are required for any portion of their operation. Under normal circumstances, only a single service through a single point of entry will be provided for each land parcel. If a Customer has more than one building on a single land parcel, it will be the

Customer's responsibility to sub-feed the additional building(s) from the single point of supply. Exceptions may be made for commercial and industrial properties with multiple, separate buildings with different supply requirements. Customers must make application to the Engineering Department to determine if more than one service to a property will be permitted.

Where more than one metered service connection is provided to a single land parcel in order to provide different supply requirements to separate buildings, and there is no electrical tie between the service connections, each connection will be treated as a separate customer for billing purposes. Where multiple feeds have been provided to a single land parcel because of limitations in London Hydro's supply capacity, or where multiple feeds have been provided for security purposes and there is an electrical connection between the feeds, all of the metered connections will be aggregated together and treated as one customer for billing purposes. Existing customers who have different supply or billing arrangements will be permitted to maintain their existing arrangement until a material change is required in one or more of the service connections.

2.3.5 Voltage Guidelines

London Hydro maintains service voltage at the Customer's service entrance within the guidelines of C.S.A. Standard CAN3-C235 (latest edition) which allows variations from nominal voltage of:

110/220 volts to 125/250 volts for 120/240V services for Normal Operating Conditions

106/212V to 127/254 V for 120/240V services for Extreme Operating Conditions

318/550V to 360/625 V for 347/600V systems for Normal Operating Conditions

306/530V to 367/635 V for 347/600V systems for Extreme Operating Conditions

Where voltages lie outside the indicated limits for Normal Operating Conditions but within the indicated limits for Extreme Operating Conditions, improvement or corrective action should be taken on a planned and programmed basis. Where voltages lie outside indicated limits for Extreme Operating Conditions, improvements or corrective action should be taken on an emergency basis. The urgency of such actions will depend on many factors such as the location and nature of load or circuit involved, the extent to which limits are exceeded with respect to voltage levels, the expected duration of the emergency, etc.

London Hydro will practice reasonable diligence in maintaining voltage levels, but is not responsible for variations in voltage from external forces such as operating contingencies, exceptionally high loads or low voltage supply from London Hydro's Transmitter or Host Distributor. London Hydro shall not be liable for any delay or failure in the performance of any of its obligations under this Conditions of Service due to any events or causes beyond the reasonable control of London Hydro, including without limitation, severe weather, flood, fire, lightning, other forces of nature, acts of animals, epidemic, quarantine restriction, war, sabotage, act of a public enemy, earthquake, insurrection, riot, civil disturbance, strike, restraint by court order or public authority, or action or non-action by or inability to obtain authorization or approval from any governmental authority or any combination of these causes. ("Force Majeure")

2.3.6 Backup Generators and other Non-Grid Connected Generators or Sources

Customers with portable or permanently connected generation capability used for emergency back-up or non-grid connected loads shall comply with all applicable criteria of the Ontario Electrical Safety Code. In particular, the Customer shall ensure that their emergency generation does not operate in parallel with London Hydro's system without a proper interface protection and does not adversely affect London Hydro's

distribution system. See Section 3.5. Please request the latest copy of the Closed Transition Switching Requirements document.

Customers with permanently connected emergency generation equipment shall notify London Hydro regarding the presence of such equipment at generation@londonhydro.com or by phone at 519-661-5800 ext. 5723.

2.3.7 Electric Metering Details & Requirements

Appendix B contains London Hydro's Operating Instruction EI-29, "Low Voltage Electric Metering Requirements" which describes London Hydro's procedures and accepted practices for the design and installation of electric metering equipment. Appendix D contains London Hydro's Engineering Instruction EI-22, "Guidelines for Supplying Interval-Style Revenue Metering Systems".

2.4 Tariffs and Charges

2.4.1 Service Connections and Miscellaneous Charges

London Hydro's policy is to develop and set average Customer charges at a level to permit full recovery of the allowable connection charges described in the OEB's Distribution System Code.

Where fixed rate average connection charges do not apply, Customers will be charged on a time and material basis to fully recover the allowable cost.

For quotes on new services and connections, please refer to the contact information in Section 1.5.

2.4.1.1 Customers Switching to a Retailer

There are no physical service connection differences between Standard Service Supply (SSS) Customers and third-party retailers' Customers. Both Customer energy supplies are delivered through the local Distributor with the same distribution requirements. Therefore, all service connection requirements applicable to the SSS Customers are applicable to third party retailers' Customers.

2.4.1.2 Payment of Connection Charges and Supply Deposits

Where connection charges or deposits apply, an irrevocable (standby) Letter of Credit or Letter of Guarantee from a chartered bank, trust company or credit union is acceptable in lieu of a cash deposit. Purchase orders in lieu of a cash payment will be accepted from the City of London only.

2.4.2 Energy Supply

2.4.2.1 Standard Supply Service (SSS)

All existing London Hydro Customers are Standard Supply Service (SSS) Customers until London Hydro is informed of their switch to a Retail Electricity Supplier. The Service Transfer Request (STR) must be made by the Customer or the Customer's authorized retailer.

2.4.2.2 Retailer Supply

Customers transferring from Standard Supply Service (SSS) to a retailer must comply with the Service Transfer Request (STR) requirements outlined in Sections 10.5 through 10.5.6 of the Retail Settlement Code.

All requests shall be submitted as Electronic files and transmitted through London Hydro's EBT system. Service Transfer Requests (STR's) must contain information as set out in Section 10.3 of the Retail Settlement Code.

If the information is incomplete, London Hydro will notify the retailer or Customer about the specific deficiencies and await a reply before proceeding to process the transfer.

2.4.3 Deposits

London Hydro is the service provider for City of London Water Services. It is understood that London Hydro's Policies, where required, will cover the water services for the purpose of receivable security subject to any City of London By-Law.

2.4.3.1 Security Requirement – Residential Customers

New residential customers are not typically required to provide security deposits. However, it is the customer's responsibility to pay their bill on time. Customers are expected to maintain a Good Payment History (GPH). London Hydro reserves the right to apply a security deposit based on a Customer's inability to maintain a Good Payment History.

All security requirements will be reviewed no less than annually. Cheques will only be issued after a final bill has been rendered and paid, excepting certain regulatory provisions. All other security adjustment including refunds due to GPH will appear on the customer's next bill. All security deposits will be returned within 6 weeks after a final bill has been rendered and all amounts owed by the customer to London Hydro have been paid. A final bill can only be rendered once London Hydro has been notified of an account status change, a forwarding address has been supplied and a final read has been made at the service location.

2.4.3.2 Security Requirement – Non-Residential (Commercial) Customers

Security must be provided to London Hydro by all General Service <50kW, General Service >50kW, >5000kW (Large User), or Embedded Generator Customers that fail to qualify for a security deposit exception and are billed by London Hydro.

Exceptions:

- i) Federal, Provincial and Municipal governments, their agencies and their guarantees.
- ii) School Boards
- iii) All new customers who have a Good Payment History (GPH) with either London Hydro (Section 2.4.5.3), another Location Distribution Company or Gas Utility in Canada. If a customer is claiming an exception due to a payment history with a non-London Hydro Inc. utility the customer must provide a letter from that utility documenting satisfactory payment history for the same legal entity. This history requirement is as follows for each customer classification:
 - 3 years for GS<50 for a full exemption
 - 7 years for GS>50 for a full exemption
 - 7 years for all other classifications for a 50% exemption

The payment history must have occurred in the past 24 months in order to qualify for an exception. Thereafter, this exception will continue to apply as long as section 2.4.5.3 is complied with.

- iv) All existing customers that maintain a Good Payment History with London Hydro Inc.
- v) At the customer's expense, they may provide an initial credit check that demonstrates they are a good credit risk, after which the customer must maintain a Good Payment History acceptable to LH. Failure to maintain a satisfactory payment history will result in an immediate security review.

2.4.3.2.1 Amount of Security

The amount of the security will be the following:

- i) For a monthly billed customer. The average monthly load over the most recent twelve-month period prorated for 2.5 months *75 days. Where an average monthly load for the customer is not available LH will calculate the load based upon its best estimate.
- ii) Where a customer is facing a security deposit requirement resulting from a poor payment history and where more than one disconnection notice has been issued, the amount of security will be calculated on the highest monthly load occurring in the immediately preceding 12 months.
- iii) LH will review annually and alter if necessary the deposit amount upon the occurrence of the following:
 - a) Lack of maintenance of Good Payment History, as defined in 2.4.5.3;
 - b) Anniversary of service installation;
 - c) A rating deterioration (see Credit Rating and Allowable Reduction table below) where the customer, at their discretion, has supplied London Hydro with a new credit check report; and/or
 - d) A significant consumption change. For example, if the original deposit is based upon historical consumption data that is inconsistent with consumption experienced with the current customer the amount of security will be adjusted once a new consumption pattern has been established.

Where a customer is facing a security deposit requirement resulting from a poor payment history and where more than one disconnection notice has been issued, the amount of security will be calculated on the highest monthly load occurring in the immediately preceding 12 months.

If requested, a Customer may pay their security deposit in four (4) equal monthly instalments.

Security Deposit assessments for Embedded Generation Customers will be evaluated by London Hydro using reasonable custom estimations of monthly load specific to the Customer.

The form of Security can be chosen by the Customer and must be in the form of cash, cheques, irrevocable and unconditional letter of credit, bank draft, or Surety Bond from a Bank as defined in the Bank Act of Canada. Security deposit amounts may be subject to additional standard charges including, but not limited to, late payment and returned item charges.

Where a non-residential Customer provides, at the Customer's expense, a credit rating from a recognized credit rating agency, the maximum amount of a security deposit which the Customer is required to pay shall be reduced in accordance with the following table:

<u>Credit Rating (Using Standard & Poor's Rating Terminology)</u>	<u>Allowable Reduction in Security Deposit Amount</u>
AAA- and above or equivalent	100%
AA-, AA, AA+ or equivalent	95%
A-, from A, A+ to below AA or equivalent	85%
BBB-, from BBB, BBB+ to below A or equivalent	75%
Below BBB- or equivalent	0%

2.4.3.3 Waiver of Security Requirement

Any customer who cannot qualify for an exception under 2.4.3 will be eligible for a 50% reduction in the security amount calculation once they enrol in a preauthorized debit plan (PAD). Any refunds of security will be applied to the Customer's next bill.

Customers who withdraw from a preauthorized debit plan will be subject to an immediate credit review.

2.4.3.4 Return of Security

All security requirements will be reviewed no less than annually. Security amounts may be returned, continued, or revised based on any of the following:

- Good Payment History, as defined in 2.4.5.3;
- A rating deterioration (See Credit Rating and Allowable Reduction table above) where the customer, at their discretion, has supplied London Hydro with a new credit check report; and/or
- A significant change in consumption. If the original deposit amount is based upon historical consumption data that is inconsistent with consumption experienced with the current customer, then the amount of security will be adjusted once a new consumption pattern has been established.

During annual review, customer's in the Large User billing classification may have 50% of the security returned if eligible due to payment history.

All security deposit related adjustments, including interest and refunds due to review, will appear on the Customer's next bill to be applied on account. For final bill customers, cheques will be issued within six weeks after a final bill has been rendered and all amounts owed by the Customer to London Hydro have been paid.

A final bill can only be rendered once London Hydro has been notified of an account status change, a forwarding address has been supplied and a final read has been made at the service location.

A customer may, no earlier than 12 months after the payment of a security deposit or on making prior demand for a review, demand in writing that London Hydro undertake a review to determine whether the total (partial) amount of the security deposit should be returned.

2.4.3.5 Security Requirement - Retailer Prudential

The Ontario Energy Board's "Retail Settlement Code", requires Distributors to enter into security arrangements with each Retailer.

All Retailers must provide a Prudential Security Deposit to London Hydro regardless of their Credit Rating.

The amount of the deposit, the type of security, and the planned frequency for prudential review for timing and updating will be set out in the "Retailer Service Agreement".

This prudential calculation will be reviewed every 3 months.

Bulk-Metered Residential Condominium Customers

When a customer is a corporation within the meaning of the Condominium Act, 1998, and has an account that relates to more than 1 unit i.e. bulk metered they will be treated as a residential customer for security deposit purposes. Customers must self declare their status as a residential condominium corporation and provide sufficient evidence to support the declaration.

2.4.3.6 Interest on Security

(For all classes with the exception of Retail Prudential which is covered under the Retail Settlement Code)

Interest shall accrue monthly on security deposits made by way of cash or cheque commencing on receipt of the total deposit required by London Hydro. The interest rate shall be at the Prime Business Rate as published on the Bank of Canada website less 2 percent, updated quarterly. The interest is accrued to December 31st of each year and applied to customer's account on December 31 or closure of the account, whichever comes first. A cheque will be issued only to those customers no longer in the London Hydro service area and whose final bill has been rendered and paid.

2.4.3.7 Payment of Security

Residential Customer – Should security be required, a customer has the option to pay the deposit over six monthly equal payments.

General Service & Large Customers – Should security be required, a customer has the option to pay the deposit over four monthly equal payments.

2.4.3.8 Other Charges

As well as asking for additional money to be added to the deposit on hand, LH will also ask the customer to pay charges, including: late payment interest charges, returned item charges, reconnection charges and other charges.

2.4.3.9 Collection Procedures

Customers with overdue accounts, in addition to having to pay a security deposit, will be subject to the standard collection procedures of London Hydro, including: notices of late payment, late payment penalties including interest charges on overdue payments, collection and agency activity, notification of credit bureaus, court action, disconnection of service, as appropriate. Services may be disconnected for non-payment of any balance including any unpaid security deposit, after proper notice has been given to the Customer. Any payments made at the door of a Customer must be made with credit card.

2.4.4 Billing

2.4.4.1 General

London Hydro will render bills to all its Customers on a monthly basis. Bills for electrical energy consumption may be based on either a metered or estimated consumption, as determined by London Hydro. Bills rendered for electricity charges with a service period of less than 15 days will include prorated monthly fixed service charges.

When an actual meter reading cannot be obtained from the meter for three (3) months, the estimated billable consumption may be inflated to obtain the customer's awareness of the repeated estimations.

Billing periods and invoice dates will be solely at the discretion of London Hydro. Customers will be billed on calendar month billing periods where one or more of the following apply:

- They are a service classified as General Service > 50 kW, Large User, or Generation Service > 50 kW
- They are considered Class A for purposes of Global Adjustment calculations (see www.ieso.ca); or
- The load is unmetered.

London Hydro requires access to a Customer's premises at all reasonable times to read meters, or to inspect, repair, or remove meters, wires, cables, or equipment owned by London Hydro. If this access cannot be obtained, the electrical service will be subject to disconnection pending arrangements to allow a reading by London Hydro's personnel.

2.4.4.2 Miscellaneous Charges

An account setup fee will be charged to cover the cost of setting up a new account and performing the final meter reading when an account is closed. The fee will also apply to all accounts that move in or transfer from one location to another within London Hydro's service territory.

Customers shall be required to pay additional charges for the processing of Non-Sufficient Fund Cheques (NSF).

A complete list of current Ontario Energy Board approved tariffs and charges applied by London Hydro can be found on our website (www.londonhydro.com).

2.4.4.3 Sundry Charges

London Hydro also bills “Sundry Charges” which are non-distribution related and can be made up of the following:

- Damages resulting from accidents to London Hydro property;
- Developer charges for existing and new developments;
- Contractor assistance;
- Sale of scrap or obsolete equipment and material; or
- Other non-distribution charges.

Sundry billing may consist of charges for labour, equipment and materials to fully recover the allowable costs.

If non-payment occurs, London Hydro will take any and all necessary steps to fully recover the charges incurred which may include refusal to work on any existing or pending projects.

2.4.4.4 Primary and Secondary Billing (Associated Billing or Deduct Billing)

London Hydro does not offer deduct billing for new services.

2.4.4.5 Billing Responsibility

It is the responsibility of the customer who will be using and/or paying the charges to enter into a contract with London Hydro via an application for service. Where a tenant has not taken this responsibility, the service will be disconnected unless the owner has a Continuous Service Agreement in place to default the account to the owner of the property.

London Hydro reserves the right to request proof of identity for all services.

Where an account is in dispute regarding bill responsibility and no one has taken liability, the service will be disconnected until the customer has taken the responsibility from the date of dispute.

When an electric service is disconnected, billing of the Fixed Monthly Fees will continue to be charged and billed to the customer for the term of their contract.

When a commercial electric service is disconnected, billing of Fixed Monthly Fees will continue to be charged and billed to the customer for the term of their contract.

Where electric service at a service location has remained disconnected continuously for six months, London Hydro may, upon notice to the Customer, close the account and terminate the contract applicable to that service location. Fixed Monthly Fees will continue to apply until the account is closed or the service connection is removed. A Customer who wishes to stop the billing of Fixed Monthly Fees before the end of the six-month period must request removal of the service connection in accordance with section 2.2.4.

Closing an account or removing a service connection does not relieve the Customer of responsibility for any outstanding amounts. If service is subsequently requested at the property, the Customer may be required to pay applicable charges approved by the Ontario Energy Board, including costs associated with restoring or installing the service connection, as well as any outstanding amounts that London Hydro is lawfully entitled to require as a condition of service. Customers are strongly encouraged to discuss the available options and associated costs with London Hydro before requesting removal of a service connection.

2.4.5 Payments and Late Payment Charges/Interest

2.4.5.1 General

Bills are rendered for all applicable services.

Consumers are provided a minimum of 20 days from the date a bill is issued to pay the bill amount in full without interest penalty.

A bill sent by mail is considered issued on the third day after being printed by London Hydro. For paperless billing Customers, a bill available through MyLondonHydro account portal is considered issued on the day London Hydro sends an email to notify the Customer their bill is ready.

Late payment charges equal to 1.5% per month (19.56% compounded annually) are calculated on all past due charges including arrears.

Where the Customer has made a partial payment on or before the due date, interest charges will apply to any outstanding amount left owing after the due date.

Payments made by mail will be considered made three days prior to the date London Hydro receives the payment.

Payments made electronically or by credit card will be considered made on the date acknowledged or recorded by the consumer's financial institution.

In the event of partial payments, payments shall be allocated to the competitive and non-competitive electricity costs based on the ratio of the amounts billed for each category, then to non-electricity costs respectively. Credit balances arising from Customer overpayments may be refunded, by cheque, at the request of the Customer. In such instances, no interest shall be applied to the amount. Customers with more than two months arrears may be ineligible for consolidated billing of electricity and non-electricity charges.

Outstanding bills are subject to the collection process and services may be disconnected. Service will be restored once satisfactory payment has been made. Disconnection of service does not relieve the customer of the liability for arrears.

2.4.5.2 Collection Procedures

Customers with overdue accounts, including unpaid security deposit, will be subject to London Hydro's standard collection procedures as follows:

- Late payment notices and penalties
- Collection and collection agency activity
- Disconnection notices
- Disconnection or limiting of service
- Notification of credit bureaus

- Court action

Any payments made at the door of a Customer must be made with certified cheque, money order, credit card, or cash.

At the time of disconnection, when a London Hydro service person comes to disconnect the service, the only option to avoid immediate disconnection is to:

- 1) Advise the service person that you will immediately make a credit card payment;
- 2) Immediately make a credit card payment in the full amount; and
- 3) Contact London Hydro Customer Services to notify us of your credit card payment.

London Hydro shall not be liable for any damages on the Customer's premises resulting from such discontinuance of service. A reconnection charge will apply where the service has been disconnected due to non-payment.

Customers shall be required to pay additional charges for the processing of Non-Sufficient Fund (NSF) cheques.

A Field Trip Charge (also known as a Collection of Account Charge) will apply whenever a visit to the Customer's premise is required to collect an overdue payment of an account or to obtain a signed application for service.

A New Account Setup Fee (or Occupancy Charge) covers the cost of setting up a new account and performing the final meter reading when an account is closed. The New Account Setup fee will apply to all customers when they contract for service at a municipal address for which they have never been contracted.

2.4.5.3 Good Payment History

The minimum time frame for establishing satisfactory payment history varies by Customer class as follows:

Customer Segment	Payment History Record
Residential	1 year
GS<50kW (Commercial)	3 Year
GS>50kW (Demand/Interval)	7 Year
Large User	7 Year

The customer will no longer qualify as a customer with a Good Payment History and will be subject to an immediate security review if any of the following events occur:

Disconnection of Service

- When a Customer has one Disconnection of Service within the relevant period stated in the above table.

Disconnection Notice

- When a Customer has been issued more than 2 disconnection notices within the relevant period stated in the above table.

Returned Payment – Insufficient Funds

- When a Customer has had 2 payments returned “Non-sufficient Funds” (NSF) within the relevant period stated in the above table.

When a Customer makes an assignment in bankruptcy or is petitioned into bankruptcy proceedings and receives court protection from creditors under any provincial or federal legislation or in any civil proceedings and has had activity that negatively impacts their payment history with London Hydro, a security deposit will be required from all such customers when court documents allow. Once their payment history becomes a “Good Payment History”, refunds will apply within the appropriate time lines depending on the classification of the customer. All customers under court protection will be subject to payment arrangements acceptable to London Hydro.

2.4.5.4 Discretion Clause

If extenuating circumstances exist and compelling reasons are demonstrated, an individual account may be reviewed by London Hydro and further accommodation may be provided.

2.4.6 Customer Class Definition and Application of Rates

All customers are to be classified according to the policies and guidelines of the Ontario Energy Board. The specific application of these policies and guidelines within the London Hydro service territory are outlined in this section.

All active services will be charged to the Monthly Service Charge.

The Ontario Energy Board approves all retail distribution and retail transmission rates for each retail customer class. Refer to Section 2.4.7 for reference to the current approved rates.

2.4.6.1 Annual Rate Class Review

To ensure fairness and uniform application of rates, it is necessary to confirm that all customers continue to be properly classified. To ensure that, London Hydro will conduct a periodic review of its customer base to determine changes to customer specific rate classifications. London Hydro will conduct a review for all customers based on the customer’s consumption during a predefined annual 12-month consumption period. The annual 12-month consumption period will normally be deemed to be between the customer’s first meter reading date occurring in October of each year through to the end meter reading date in October of the next year, unless otherwise specified. Normally, a customer rate reclassification review will occur in November of each year with the first change being made after January 1st of the new billing year.

Interim reviews of a customer’s rate classification can be made at any time at either London Hydro’s discretion or upon request by the customer, but not more frequently than once per calendar year. Customers classified as GS>50 kW with a forecasted demand of greater than 5,000 kW will be changed to a Large User classification immediately following any period in which their demand first exceeds 5,000 kW. Otherwise an interim review would be based on the preceding consecutive months, using load data for a minimum of 5 months but no greater than a maximum of 12 months. If an annual or interim review requires a customer to

be moved into a different rate class, London Hydro will notify the customer of the rate reclassification a minimum of one bill period before the reclassification is being made. Rate reclassifications apply only to future charges; neither London Hydro nor the customer can charge or recover monies for payments made during the 12-month period preceding a review and rate reclassification.

Classification of Rates – Change in Use

When the use of a facility or electric service changes, the rate classification may also need to change to ensure fair and uniform application of rates (e.g. residential to commercial rate classifications). It is the responsibility of the customer to notify London Hydro immediately if the premise where electric service is provided is modified or altered in any way so as to result in a change to the rate class for which the service is qualified according to the policies and guidelines of the Ontario Energy Board Electricity Distribution Handbook, which can be viewed at www.oeb.ca.

London Hydro at its sole discretion will audit customer rate classifications and facility or service use through periodic field investigations. If it is identified that the rate classification does not match the service use, London Hydro reserves the right to change the customer's rate classification to the appropriate rate class. In addition, if it is found that the facility use change occurred without notification from the customer, London Hydro reserves the right to apply the rate reclassification retroactively up to two years. London Hydro will notify the customer of the rate reclassification at least one bill period prior to the reclassification.

Note: as outlined above it is the customer's responsibility to advise London Hydro of the property or service.

2.4.6.2 Temporary Services

Customers will be classified into the temporary service classification whenever their billing period will be less than 12 months of consecutive service. The consecutive service period is defined as the time between when the electric service becomes activated by a customer for billing to the time the service becomes deactivated and the billing to the customer ceases. Initial customer rate classification will be determined by using the best available criteria from use of either forecasted consumption data, historical consumption data derived from typical/similar customer use when available or through the use of the Application of Rates and Charges, outlined in Chapter 9 of the OEB Rate handbook. For determining the appropriate customer rate class for temporary service customers, the evaluation process will use less than 12-month consumption averages for determining the appropriate rate class to be applied.

For new services expected to have a monthly demand greater than 50kW, an interval meter will be installed. Typically this will be provided with a cellular communication option and related fees as described in section 2.4.11.3.5, *General Service >50kW Interval Meter*.

There are two major sets of categories under which London Hydro must classify its customers and apply rates. These categories are distribution services and transmission services. The distribution services relate to the actual distribution system that London Hydro utilizes to provide services directly within the service territory. The transmission services are related to the infrastructure of both the transmission system and provincial electric market operations to provide service to the London Hydro service territory.

For each major category a definition of customer classes and rate applications are required.

Temporary services are required to adhere to the same technical requirements as permanent services.

2.4.6.3 Retail Distribution Billing Determinants

2.4.6.3.1 Residential – Energy Metered and General Service < 50 kW – Energy Metered

All non demand customers without interval meters will be deemed to be Residential – Energy Metered or General Service < 50 kW – Energy Metered. This rate class will include all residential customers and general service customers with either a 12-month average annual consumption period peak demand of less than 50 kW per month or projected average peak demand of less than 50 kW per month for new customers.

Any of the above class of customers that install an interval meter will be deemed to be on the same retail distribution rate schedule and rate application as this customer rate class. The service charge will be applied on a per (electric service) connection basis. See Section 2.3.5 for a further discussion of billing arrangements for customers with more than one metered service connection.

Multi-unit residential establishments such duplexes, triplexes, and apartment buildings supplied through one service (bulk meter) shall be classified as general service.

Where electricity service is provided to combined residential and business (including agricultural) usage and the wiring does not provide for separate metering, the classification shall be at the discretion of the utility and should be based on such considerations as the estimated predominant use of consumption.

2.4.6.3.2 Sentinel Lighting & Un-metered/Scattered loads

Sentinel Lighting & Unmetered/Scattered loads will be defined as the unmetered (Non-Streetlight) service accounts with London Hydro. The demand kW rate will be applied on an estimated peak (connected load) demand occurring at any time of the month and the monthly service charge will be applied on a per connection basis. See Section 2.3.5 for a further discussion of billing arrangements for customers with more than one metered service connection.

2.4.6.3.3 Street Lighting

Street Lighting will be defined as the unmetered street light service accounts with London Hydro. The demand kW rates will be applied on an estimated peak (connected load) demand occurring at any time of the month. The service charge will be on a per connection basis.

2.4.6.3.4 General Service >50kW Interval Meter

This rate class will include all general service interval metered customers with a 12-month average annual consumption period peak demand of greater than or equal to 50 kW per month or projected average peak demand of greater than or equal to 50 kW per month for new customers and having an annual consumption period demand of less than 5,000 kW per month or projected average peak demand of less than 5,000 kW per month for new customers.

The billing demand of a General Service – Interval Metered customer shall be based on the peak demand in kilowatts during any 15 minute interval in the bill period, as recorded on an interval meter. The measured demand shall be adjusted for transformer losses and power factor as applicable to determine the billing demand. The billing demand will be determined by the higher of 90% kVA or 100% kW (Power factor adjusted) and shall be adjusted for 1% transformer losses when the metering installation is deemed to be primary metered (Primary Meter = Meter on supply side of the transformer).

The service charge will be applied on a per (electric service) connection basis.

Some General Service accounts may be eligible for the Regulated Price Plan (RPP). Eligibility for designation is in accordance with the definitions outlined in the Ontario Energy Board Act, 1998, and Ontario Regulation 95/05. Customers that leave the regulated price plan for any reason may be subject to a "Final Regulated Price Plan (RPP) Variance Settlement Factor." This settlement factor may be a credit or a charge based on the current factor issued by the Ontario Energy Board and is to be included in the first bill issued after the Customer is removed from designation status.

To determine the billing demand, the measured peak demand will be adjusted for primary or secondary transformer losses as appropriate. Primary transformer losses apply when the metering installation is on the supply side of the transformer.

Measured demand will be Power Factor Adjusted to determine billing demand (i.e. the higher of 90% kVA or 100% kW).

2.4.6.3.5 Large User > 5,000 kW - Interval Meter

Customers with a monthly peak demand averaged over 12 consecutive months equal to 5,000 kW or greater shall be classified as large user. Where forecast demands clearly establish that a customer would become a large user, the customer may be classified as a large user as soon as the peak demand exceeds 5,000 kW. Normally, a customer's classification will be reviewed annually at the end of the calendar year.

The billing demand of a large user customer shall be based on the peak demand in kilowatts during any consecutive 60 minutes (Rolling 60-Minute Averages) in the bill period as recorded on an interval meter with a demand interval of either 5 or 15 minutes. The measured demand will be adjusted for transformer losses and power factor as applicable to determine the billing demand. The billing demand will be determined by the higher of 90% kVA or 100% kW (Power factor adjusted) and shall be adjusted for 1% transformer losses when the metering installation is deemed to be primary metered (Primary Meter = Meter on supply side of the transformer).

The service charge will be applied on a per (electric service) connection basis.

2.4.6.3.6 Embedded Generation

Embedded generation, co-generation or load displacement generators have the option to reserve demand capacity on the London Hydro distribution system for import load through a mutual agreement/contract. The customer's contracted reserve amount shall not exceed the generator(s) nameplate capacity rating. The customer can make a request to change the reserve amount annually. The distribution standby rate will be applied to all monthly kW reserved before any transformer discounts for customer owned equipment. The transformer discount will be applied to all kW reserved or billed when the customer owns their own transformation. The transformer discount will be applied to all incremental distribution kW's billed when the customer owns their own transformation and the customer is classified within the London Hydro OEB approved General Service 50 - 4,999 kW (Co-generation) rate category.

For the embedded generation customers with an annual average gross peak demand of greater than 1,000 kW per month the co-generation distribution rates will apply for those customers meeting the following conditions:

1. The generation is in operation at least 20% of the London Hydro determined annual rate reclassification period and;

2. The installed generation is at least 20% of the customers load requirements and;
3. The customer wishes to reserve capacity (Standby reserve) on the London Hydro system.

The distribution kW rate is applied to the incremental billed demand. Incremental billed demand is equivalent to the gross peak monthly billed demand less the standby reserve kW.

The monthly measured gross peak demand will be determined by the higher of 90% kVA or 100% kW (Power factor adjusted) and shall be adjusted for 1% transformer losses when the metering installation is deemed to be primary metered (Primary Meter = Meter on supply side of the transformer).

The billed demand will be determined by the measured gross peak demand occurring during any time of the billing period (i.e. month). The service charge will be applied on a per (electric service) connection basis.

When gross peak demand is determined to be over an annual average of 5,000 kW per month, the billing demand will be based on the maximum demand during any consecutive 60 minutes (Rolling 60-Minute Averages) in the bill period.

When gross peak demand is determined to be less than an annual average of 5,000 kW per month, the billing demand will be based on the gross peak demand during any 15 minute interval in the bill period.

For the embedded generation customers with a gross peak demand annual average of less than 1000 kW and greater than 50 kW per month, the general service > 50 kW distribution rates will be applied, as long as there is no requirement for reserve capacity from the customer.

For the embedded generation customers with a gross peak demand annual average of less than or equal to 50 kW per month, the general service < 50 kW or residential distribution rates will be applied, as long as there is no requirement for reserve capacity from the customer.

For embedded generators that have a single unit greater than 1000 kW in capacity that use a non-renewable fuel source or those embedded generators that have a single unit greater than 2000 kW in capacity that use a renewable fuel source, the customer is required to meter the generation and provide London Hydro with access to the interval data. London Hydro recommends the customer engages a metering service provider (MSP) and enables London Hydro to read the meter.

2.4.6.3.7 Embedded Distributor

In the case of embedded distributors, application rates will be based on Gross Peak Demand.

When the actual or forecasted (new services) 12 month average Gross Peak Demand is:

- less than 50 kW - General Service < 50 kW Service Classification rates will apply
- less than 5,000kW - General Service >50 KW Service Classification rates will apply
- greater than or equal to 5,000kW - Large Use Service Classification rates will apply

2.4.6.3.8 Transformer Allowance

The transformer allowance will be applied to all kW demand reserved or billed when the GS>50 kW customer owns their own transformation.

2.4.6.3.9 Specific Service Charges

All specific service charge rates will be applied as outlined in the distribution rates schedules approved by the Ontario Energy Board.

2.4.6.4 Retail Transmission Billing Determinants

The application of demand rates identified in this Section follows the requirements outlined in the Hydro One Networks Inc., (HONI) Transmission Rate Schedules, OEB Distribution Rate Handbook and the OEB RP-1999-0044. For generation customers the use of coincidental demand variables and rules will only be applied to those customers that fall within the OEB approved Co-generation rate classification or any existing generation installed on or before October 31, 1998; otherwise the gross peak and on-peak demands will be used to determine demand variables.

2.4.6.4.1 Residential - Energy Metered, General Service < 50 kW - Energy Metered and Un-metered Scattered Loads

All non-demand customers without interval meters will be deemed to be Residential – Energy Metered or General Service < 50 kW – Energy Metered. This rate class will include all residential customers and general service customers with either a 12-month average annual consumption period peak demand of less than 50 kW per month or projected average peak demand of less than 50 kW per month for new customers. The rates will be applied to all energy adjusted for the total loss factor set out under the Retail Settlements Code.

Any of the above class of customers that install an interval meter will be deemed to be on the same retail transmission rate schedule and rate application as the Residential - Energy Metered and General Service < 50 kW - Energy Metered. As the number of interval metered customer's increase in these rate classes, a redefinition of the application could be made once coincident factor data is available.

2.4.6.4.2 Sentinel Lighting

Sentinel Lighting will be defined as the un-metered sentinel light service accounts with London Hydro and the rates will be applied on a connected load basis.

2.4.6.4.3 Street Lighting

Street Lighting will be defined as the un-metered street light service accounts with London Hydro and the rates will be applied on an average monthly-connected load basis.

2.4.6.4.4 General Service >50kW Interval Meter

This rate class will include all interval-metered customers with an annual average calendar year monthly demand of greater than or equal to 50 kW or less than 5,000 kW.

The billing demand for a General Service - Interval Metered customer shall be based on the metered demand or connected load after necessary adjustments for power factor, intermittent rating, transformer losses and minimum billing. This measurement, in kilowatts (kW) or kilovolt-ampere (kVA), reflects the maximum rate at which electricity is consumed during a billing period measured over a specified time interval. Typical demand intervals are 15, 30 and 60 minutes.

The billed demand for network retail transmission service charges will be determined by the measured on-peak demand occurring during the peak periods of 7 am to 7 pm (local time) on weekdays excluding holidays as defined by the Hydro One Networks Inc., Transmission Rates Schedule.

The billed demand for connection retail transmission service charges will be determined by the measured on-peak demand occurring during any time of the billing period (i.e. month) as defined by the Hydro One Networks Inc., Transmission Rates Schedule.

2.4.6.4.5 Large User > 5,000 kW – Interval Meter

A customer with an anytime peak demand equal to 5,000 kW or greater, shall be classified as large user. Where forecast demands clearly establish that a customer would become a large user, the customer may be classified as a large user as soon as the peak demand exceeds 5,000 kW. Normally a customer's classification will be reviewed annually at the end of the calendar year.

The billing demand of a large user customer shall be based on the peak demand in kilowatts during any consecutive 60 minutes (Rolling 60-Minute Average) in the month as recorded on an interval meter with a demand interval of either 5 or 15 minutes. The measured demands for both connection and network retail transmission service charges shall be adjusted for transformer losses and power factor as applicable to determine the billing demand. The billing demand will be determined by the higher of 90% kVA or 100% kW (Power factor adjusted) and shall be adjusted for 1% transformer losses when the metering installation is deemed to be primary metered (Primary Meter = Meter on supply side of the transformer).

The billed demand for network retail transmission service charges will be determined by the measured on-peak demand occurring during the peak periods of 7 am to 7 pm (local time) on weekdays excluding holidays as defined by the Hydro One Networks Inc., Transmission Rates Schedule.

The billed demand for connection retail transmission service charges will be determined by the measured peak billed demand occurring during any time of the billing period (i.e. month) as defined by the Hydro One Networks Inc., Transmission Rates Schedule.

2.4.6.4.6 Generation (Existing > 1,000 kW & Existing or New < 1,000 kW)

Existing embedded generation is defined as those generators with required approvals for such generation before October 30, 1998. Embedded generation < 1,000 kW will be those generators installed at any time with a generation rating of 1,000 kW or less and have an interval meter installed on the service entrance.

For existing embedded generation customers with a generation rating of greater than 1,000 kW, the retail transmission rates and rate applications for Generation (Existing > 1,000 kW & Existing or New < 1,000 kW) will apply to all customer import/consumed energy taken from the London Hydro distribution system.

For customers with a generation rating of 1,000 kW or less wishing to be classified as an embedded generator for determining transmission rate applications, the generation customer must meet all of the following conditions:

1. The service must be monitored via an approved interval meter.
2. The generator must be in operation at least 20% of the London Hydro determined annual rate reclassification period.
3. The installed generation must be at least 20% of the customers load requirements.

Retail Network Service Charge – rates applied to the measured coincidental net energy consumed during the clock hour at time of either the higher of the transmission system peak or 85% delivery point peak between the peak time hours of 7 am to 7 pm (local time) on weekdays excluding holidays as defined by the Hydro One Networks Inc., Transmission Rates Schedule.

The billing demand will be determined by the higher of 90% kVA or 100% kW (Power factor adjusted) gross peak demand and shall be adjusted for 1% transformer losses when the metering installation is deemed to be primary metered (Primary Meter = Meter on supply side of the transformer).

Retail Connection Service Charge – rates applied to the measured coincidental net energy consumed during the clock hour at the time of their delivery point peak. The billing demand will be determined by the higher of 90% kVA or 100% kW (Power factor adjusted) gross peak demand and shall be adjusted for 1% transformer losses when the metering installation is deemed to be primary metered (Primary Meter = Meter on supply side of the transformer).

The connection import demand will be determined by the billing import demand, which will be determined by the highest of either 90% kVA or 100% kW (Power factor adjusted) gross peak demand. Import demand shall be adjusted for 1% transformer losses when the metering installation is deemed to be primary metered (Primary Meter = Meter on supply side of the transformer).

2.4.6.4.7 Generation (Energy Metered Customer <50 kW)

For generation customers with a demand <50 kW the retail transmission network and connection energy rates will apply for the general service <50 kW and residential classes on consumed uplifted¹ energy.

2.4.6.4.8 Generation (New >1,000 kW)

New embedded generation >1,000 kW is defined as those generators with required approvals for such generation after October 30, 1998 and that have a generation rating of greater than or equal to 1,000 kW.

Retail Network Service Charge – rates applied to the measured coincidental net energy consumed during the clock hour at time of either the higher of the transmission system peak or 85% delivery point peak between the peak time hours of 7 am to 7 pm (local time) on weekdays excluding holidays as defined by the IESO.

The network billing demand will be determined by the higher of 90% kVA or 100% kW (Power factor adjusted) gross peak demand and shall be adjusted for 1% transformer losses when the metering installation is deemed to be primary metered (Primary Meter = Meter on supply side of the transformer).


Retail Connection Service Charge – rates applied to the measured coincidental gross² energy consumed during the clock hour at the time of their delivery point peak. The billing demand will be determined by the higher of 90% kVA or 100% kW (Power factor adjusted) gross peak demand and shall be adjusted for 1% transformer losses when the metering installation is deemed to be primary metered (Primary Meter = Meter on supply side of the transformer).

¹ Uplifted: defined as being the metered energy is uplifted by the OEB distribution total loss factor (TLF x kWh).

² Gross: defined as the gross energy consumed on the clock hour and derived as imported (Consumed) energy plus generation less exported (Received) energy. The received energy is defined as the energy exported to the distribution system.

2.4.6.4.9 Generation (Combination of Existing and New > 1,000 kW)

There may be incidences where a generator is connected with both existing and new generation behind the customer's main meter (Meter 1), as outlined in Sections 2.4.6.4.6 and 2.4.6.4.8 above and described in the following graphical presentation:



For settlements of an embedded generation customer with both existing and new generation the following rule will apply for determining the gross billing demand, when considering transmission connection charges:

The transmission connection gross billing demand will be determined as,

Transmission connection demand being equal to the coincidental energy in (EI) plus the output of the new generation (M2) less energy exported out to the distribution system (EO) and if EO is greater than M2 let the allocated energy exported to the distribution system from the new generation (EA) equal M2.

The billing demand formula for connection charges to the embedded generation customer will be as follows, with demands recorded on the clock hour coincident with the delivery point connection peak time:

$$TC = EI + M2 - EA, \text{ IF } EO > M2 \text{ then } EA = M2 \text{ else } EA = EO$$

Retail Connection Service Charge – rates applied to the measured coincidental gross energy consumed during the clock hour at their delivery point peak. The billing demand will be determined by the higher of 90% kVA or 100% kW (Power factor adjusted) gross peak demand and shall be adjusted for 1% transformer losses when the metering installation is deemed to be primary metered (Primary Meter = Meter on supply side of the transformer).

2.4.7 Distribution Rates

The Ontario Energy Board must approve all rates and charges that London Hydro applies.

The following are the types of rates and charges that are approved by the OEB:

- Loss Factors
- Retail Distribution Rates
- Retail Transmission Rates
- Wholesale Market Service Rate
- Standard Supply Service Rates
- Miscellaneous Rates and Charges

See Appendix E for the current copy of the OEB approval for each of the above referenced rate categories.

For generators wishing to participate in the market as retail embedded and receive payment for their electricity delivered to the London Hydro distribution system all conditions outlined in Section 3.2 of the Retail Settlement Code must be met by the generator.

RSC Section 3.2- "A distributor shall enter into an agreement to purchase energy from an embedded retail generator within its service area, where such generator has indicated that it intends to generate electricity for sale directly to such distributor and that it has obtained such licences from the Board for generating and wholesaling electricity as are required. The contract shall specify that the generator must meet the technical and metering requirements set out in the Distribution System Code. The price under the agreement at which all energy sales shall be settled will be the competitive electricity price as described in Appendix "A" to the Code ..."

2.4.8 Energy Rates

2.4.8.1 Energy Rates for Consumed Energy

For all non-regulated price plan (NRPP) customers¹, the rules for applying commodity charges for energy consumed by the customer will be dictated by the requirements outlined in the OEB Retail Settlement Code.

2.4.8.1.1 Regulated Price Plan Customers

For all regulated price plan (RPP) customers², the rules for applying commodity charges for energy consumed by the customer will be dictated by the requirements outlined in the OEB Standard Supply Service Code and at rates defined in the OEB approved RPP rate schedules.

2.4.8.2 Consumption of Energy by Generation Customer

For all non-regulated price plan embedded generation customers, the rules for applying commodity charges for energy consumed by the generation customer will be dictated by the requirements outlined in the OEB Retail Settlement Code, in the same manner as all other load-consuming customers.

For all regulated price plan embedded generation customers, the rules for applying commodity charges for energy consumed by the generation customer will be dictated by the requirements outlined in the OEB Standard Supply Service Code and at rates defined in the OEB approved RPP rate schedules, in the same manner as all other load-consuming customers.

2.4.8.3 Payments for Energy Received from Generation Customer

The rules for compensating generators for excess energy exported to the distribution system will be dictated by the requirements outlined in Section 3.2 and Appendix A of the OEB Retail Settlement Code.

¹ Non-regulated price (NRPP) customer: All SSS or Retailer associated customers that are not eligible to participate in the RPP or have elected to opt of the RPP.

² Regulated price plan (RPP) customer: Low volume and designated customers that meet participant criteria defined in the OEB SSSC and Ontario Legislation or Regulation.

2.4.8.4 Payments for Energy Received from “net metered” Customers under O. Reg. 541/05 – Generation Customer

For all “net metered” eligible customers, Ontario Regulation 541/05, latest revision, will define the rules for compensating eligible¹ renewable generation customers for excess energy exported to the system.

2.4.8.5 Payments for Energy Received from Community Net Metered Customers under O. Reg. 679/21 Community Net Metering Project

For all community net metered eligible customers, Ontario Regulation 679/21, latest revision, will define the rules for compensating eligible renewable generation customers for excess energy exported to the system.

2.5 Customer Information

A third party who is not a retailer may access historical usage information when provided with “delegate” access to London Hydro’s customer engagement applications by the Customer.

London Hydro will provide information appropriate for operational purposes that has been aggregated sufficiently, such that an individual's Consumer information cannot reasonably be identified, at no charge to another Distributor, the transmitter, the IESO or the OEB. London Hydro may charge a fee that has been approved by the OEB for all other requests for aggregated information.

At the request of a Consumer, London Hydro will provide a list of retailers who have Service Agreements in effect within its distribution service area. The list will inform the Consumer that an alternative retailer does not have to be chosen in order to ensure that the Consumer receives electricity and the terms of service that are available under Standard Supply Service.

Upon receiving an inquiry from a Customer connected to its distribution system, London Hydro will either respond to the inquiry if it deals with its own distribution services or provide the Customer with contact information for the entity responsible for the item of inquiry, in accordance with Chapter 7 of the Retail Settlement Code.

An embedded Distributor that receives electricity from London Hydro shall provide load forecasts or any other information related to the embedded Distributor's system load to London Hydro, as determined and required by London Hydro.

3 CUSTOMER SPECIFIC

3.1 Residential

This section is divided into three categories of residential services: single-family or single-unit homes, multi-family buildings, and subdivision developments.

3.1.1 Single-Family Residential - General

Single-family residential dwelling units will be provided with a basic connection to London Hydro's electric system without charge as long as the meter base is located in the standard location, no further than 3 metres from the front corner of the dwelling, on the side closest to London Hydro's supply transformer. The basic connection includes the supply and installation of overhead distribution transformer capacity or an equivalent

¹ Eligible: customer must meet all distribution and Provincial requirements

credit for transformation equipment and up to 30 metres of overhead conductor or an equivalent credit for underground services. To obtain the fee for non-standard locations, contact the New Services and Connections using the information provided in Section 1.5.

For the purpose of determining whether a basic connection is provided free of charge or whether a commercial service charge applies, a single family residential dwelling must be zoned residential by the City of London, must be used for dwelling purposes, and must have only one electric meter. Any costs associated with modifying a service to a residential dwelling unit to add additional meters will incur General Service (Commercial) connection costs as described in Section 3.2.

Energy supplied to residential dwellings will be single phase, 3 wire, 60 Hz, having a nominal voltage of 120/240 volts, up to a maximum 200 amps per dwelling unit. Only one electrical service will be permitted per dwelling.

3.1.1.1 Early Consultation

Where a new service is required, the Customer must supply London Hydro with the following information well in advance of the date when the service will be required:

- i) required in-service date
- ii) requested service entrance capacity and voltage rating of the service entrance equipment
- iii) locations of other services such as gas, telephone, water, cable TV, underground sprinkler systems, etc.
- iv) details respecting heating equipment, air conditioners and any appliances which demand a high consumption of electrical energy
- v) a survey or site plan indicating the proposed location of the service entrance equipment with respect to public rights of way and lot lines.

Customers requesting a disconnect or reconnect of an existing service to permit a service upgrade should refer to Appendix A "Disconnection and Reconnection of Residential Meters and Service Cables".

3.1.1.2 Point of Demarcation

For the purpose of this section, the points of demarcation described below refer to both the ownership and maintenance (operational) demarcation point.

The point of demarcation for residential overhead services is at the connection point where London Hydro's service drop connects to the Customer's anchor point and service mast weatherhead. London Hydro is responsible for the electrical maintenance and repair of the transformer, transformer hardware and the overhead service wire. The Customer is to contact London Hydro if they wish to have tree trimming maintenance around the London Hydro overhead service wire. The Customer is responsible for the maintenance and repair of the anchor point, weatherhead and all points downstream of the connection splice including the meter socket base and the jaw and connection block assemblies. London Hydro is responsible for the maintenance and repair of the electric meter.

The point of demarcation for residential underground services is at the meter. London Hydro is responsible for the maintenance and repair of the transformer, transformer hardware, the underground secondary cable and the electric meter. The Customer is responsible for the maintenance and repair of the meter socket

base, the meter jaw and connection block assemblies and all equipment downstream. The Customer is also responsible for the conduit that guides the service cable from underground to the meter base.

For Customers who have service entrances with recessed meter bases and 'Amalgamated' switches, combination panels or a similar configuration, London Hydro's service cables enter the Customer's disconnect switch ahead of the meter. In these instances, the Customer is also responsible for the maintenance and repair of the disconnect switch or combination panel.

For Customers whose service entrance is located more than 100 metres from the right-of-way, a high voltage primary line (either overhead or underground) will be required. The Customer will be responsible to own and maintain the primary portion of the line unless they elect to pay a 20% premium on the initial cost of the primary line to transfer the ownership and future maintenance responsibilities to London Hydro. If the Customer is responsible to maintain the primary line, the point of demarcation for overhead lines is at the first pole and the point of demarcation for underground lines is at the primary cable riser connection. The Customer is responsible for the maintenance and repair of all poles, primary conductors and hardware, (including regular tree trimming), primary cable terminators, cable hangers, and primary cables in addition to the equipment listed in the first two paragraphs of this section. London Hydro is responsible for the transformer, transformer hardware, the civil components associated with padmounted transformers (slab, pull box, grounding), and the first 30m of overhead secondary wire. London Hydro will be responsible for maintaining all residential overhead and underground residential secondary conductors (unless otherwise specified).

In all cases, if a Customer requires a primary line on their property, the Customer must sign a Connection Agreement that will describe in detail which party is responsible for the maintenance of various components of the line.

3.1.1.3 Servicing Details

The Customer or the Customer's electrical contractor must contact London Hydro to arrange a mutually agreeable service location and supply service arrangement.

i) Overhead Services

Arrangements for a service layout for overhead service conductors may be made through the Operations Administration Department at (519) 661-5555.

In overhead supplied areas, London Hydro will install overhead service wires from its aerial circuits on the public right of way at no charge to the Customer if the distance between London Hydro's supply point and the Customer's service entrance is not more than 30 metres. If the distance is greater than 30 metres, the Customer will incur a charge for additional material and labour. For a quote on additional charges, contact New Services and Connections using the information provided in Section 1.5. If a pole or poles and any other attachments are required on the Customer's property to support, anchor or terminate the service conductors, these shall be supplied and installed at the Customer's expense.

If the distance is greater than 100 metres, the Customer will be required to construct a primary voltage pole line on their property to support the circuit. The Customer will have a choice to either own and maintain this line or to pay a 20% premium on the initial cost of the line to transfer the ownership and future maintenance of the line to London Hydro as described in Section 3.1.1.2. London Hydro will make the connection to London Hydro circuits on the public right-of-way. If a transformer is required, London Hydro will supply the transformer and will install up to 30m of secondary service cable. The Customer will be responsible for the installation and maintenance of all poles, hardware, primary conductors (including regular tree trimming).

The Customer will also be required to sign a Connection Agreement with London Hydro. Connection charges can be obtained by contacting New Services and Connections using the information provided in Section 1.5.

The permissible height for the service wires entering the residential dwelling is a minimum of 4.5 meters above the finished ground level. Higher elevations may be required to ensure proper clearance over driveways or from windows and other obstructions.

A Customer will be responsible to supply and install all equipment for the anchoring of the service wires near the service weatherhead. This will include a through bolt and insulator for the service attachment.

The Customer must locate the service conduit head not further than 1 meter from the corner of the building closest to London Hydro's supply point. The Customer's service conductors must run from the meter socket through the service conduit riser with at least 0.6 meters of conductor extending from the weatherhead to provide for connection to the service drop with an adequate drip loop.

The location of the service point of attachment must be such that the service wires will not cross over any part of the building, additions, out buildings, awning, or any place that is not accessible by London Hydro employees. The point of attachment must also be accessible by ladder.

ii) Underground Services

Arrangements for service layouts for underground supply service conductors may be made through the Operations Administration Department at (519) 661-5555.

In underground residential areas, London Hydro will install underground service wires for a fee if the distance from the property line to the Customer's service entrance is not more than 30 metres. The fee will be provided by contacting New Services and Connections using the information provided in Section 1.5 and represents the cost of the underground service less a credit for an equivalent basic overhead connection. A fee also applies if the service is not installed in the standard location, within 3 meters of the front corner of the building, on the side closest to London Hydro's supply transformer.

In areas that are supplied with overhead circuits, a Customer may request an underground service and must meet the following conditions:

- a) The Customer must arrange for a service layout, obtain approval for a proposed trench layout and provide a measurement for the length of secondary cable required. London Hydro will supply the secondary cable and deliver it to the jobsite for installation in the trench by the Customer.
- b) The Customer is responsible for digging the trench and ensuring that the backfill is free of debris (bricks, stones, etc.). London Hydro will supply, but the Customer is responsible to lay 75mm rigid PVC conduit in the trench. If the native material is unsuitable for backfill, the Customer is responsible to install 6 inches of sand bedding and cover. The trench must be a minimum of 36 inches in depth and 6 inches in width. London Hydro will advise the Customer of minimum clearances required from London Hydro's distribution equipment. The conduit material will be billed to the customer.
- c) London Hydro will supply but the Customer is responsible to install a 50 mm (2 inch) rigid polyvinyl chloride (PVC) conduit from the base of the meter socket to at least 1 metre below finished grade. The service entrance and meter location must be located not further than 3m (10 ft.) from the corner of the building closest to London Hydro's supply point.

- d) London Hydro will supply but the Customer is responsible to install the secondary cable inside the conduit with a minimum of a 2 foot loop at the base of the meter (to allow for frost heave) and London Hydro will supply mechanical protection and a weatherhead for installation on London Hydro's pole. London Hydro will install the mechanical protection and the weatherhead.
- e) If a pole is required on the customer's property to support the underground dip, or if boring costs are incurred to cross a roadway, or if any other costs are required over and above the cost of an equivalent overhead connection, these will be at the customer's expense.
- f) London Hydro will be responsible for proper civil inspection with "sign off" prior to terminating the secondary cable at the overhead circuit and on the line side of the Customer's meter base.
- g) Material described above supplied by London Hydro will be at the customer's expense.
- h) For services greater than 30m in length an additional charge per meter will be added. Quotes will be provided by contacting New Services and Connections, refer to Section 1.5 for contact information.
- i) For services greater than 100m in length please see Section 3.1.1.2.

London Hydro will own, operate and maintain the underground secondary cable provided there is reasonable access to the underground plant. The Customer will be responsible to remove and reinstate any privately owned obstructions (landscaping, sprinklers and sprinkler piping, sheds, buildings, etc.) if required for access. To avoid open cut driveways to repair future cable faults, an appropriate electrical conduit crossing will be accepted. Under no circumstances will drainage pipe be permitted.

In the event of a fault on the Customer's underground supply or an adjacent Customer's supply, London Hydro reserves the right to install temporary jumper cables from either a Customer's or a neighbouring Customer's service to maintain power to the affected Customer until the fault is repaired. The connections are made on the line side of the meter and do not affect consumption charges.

For services larger than 200 A, single phase, London Hydro will supply and install parallel secondary cables. Two 50 mm (2 inch) rigid polyvinyl chloride (PVC) conduits must be supplied by the Customer as well as an indoor main disconnect switch. London Hydro will install the secondary cables up through the entrance conduit into the Customer-owned switch and make the connections on the line side. For services larger than 200 A, contact New Services and Connections for a quote, refer to Section 1.5 for contact information.

3.1.1.4 Metering

All of the requirements for metering single family residential dwellings are discussed in Appendix B "Low Voltage Electric Metering Requirements".

3.1.2 Multi-Family Residential

For the purpose of this document, multi-family residential dwellings are defined as buildings containing more than one single family dwelling unit that are either individually metered or are metered with a bulk meter and have a service entrance capacity greater than 200 amps.

Multi-family residential dwellings fall under the General Service (Commercial) classification and connection charges will apply as described in Section 3.2. Please refer to the appropriate General Service section of this document for the conditions of service that apply to multi-family residential dwellings.

3.1.2.1 Metering

Please refer to Appendix B "Low Voltage Electric Metering Requirements" for details on London Hydro's metering requirements.

3.1.3 Residential Subdivision Developments

Electrical service facilities for single family and multi-family townhouse and condominium residential developments will be installed underground consisting of mini-padmout transformers and primary/secondary conductors. Any variation in service will require London Hydro's review and approval. London Hydro will provide and install the complete distribution system including services to the line side of the Customer's meter base. The entire distribution system will be operated and maintained by London Hydro.

Early consultation with London Hydro is essential to avoid delays in servicing this type of development. London Hydro requires a minimum notice of 16 weeks prior to the required in-service date. The subdivider/developer is required to provide a site servicing plan and a lot grading plan for the placement of padmount transformers. If the area described by a Registered Plan will be developed in stages, it is important for each stage or portion of work to be given a designation that is understood and accepted by all parties.

London Hydro will design a subdivision electrical servicing layout and the subdivider/developer will have the opportunity to review London Hydro's design prior to installation. Minor changes are permitted as long as they do not compromise London Hydro's standards and practices.

London Hydro will require the subdivider/developer to authorize the installation through a "Joint Services Letter" process. This letter must be signed by the subdivider/developer before construction starts. The subdivider/developer must sign the final distribution drawings from London Hydro and provide grade levels for all above ground equipment to be installed.

The subdivider/developer must provide easements as required by London Hydro. For multi-family townhouse and condominium developments, a blanket easement will be required for the entire project site as a Condition of Service. (See Section 2.1.6).

In most cases, telephone, cable TV, and street lighting cables will be installed jointly during the electrical construction installation. London Hydro will facilitate the coordination process for the projects constructed by London Hydro but the subdivider/developer is responsible for meeting the requirements of Bell Canada, Rogers Cable, and the City of London with respect to the installation of their services. London Hydro is not responsible for the design of any of these systems. For all projects where the customer elects to use the alternative bid process it will be customers' responsibility to facilitate the joint trench coordination process.

The subdivider/developer will be required to make a capital contribution towards the installation as described in Section 2.1.2. The applicable charges will be provided through a quote from New Services and Connections; refer to Section 1.5 for contact information.

For details regarding service voltage, point of demarcation, access and service locations see Section 3.1.1.

3.2 General Service

This section describes the Conditions of Service applicable to General Service Customers. General Service Customers are also known as Commercial Customers and this section applies to all Customers other than single family residential Customers described in Section 3.1.1. London Hydro specific requirements for connecting Electric Vehicle Supply Equipment (EVSE) are outlined in Appendix F.

3.2.1 Early Consultation

Early consultation with London Hydro is essential since it's difficult to document all of the circumstances and conditions of service that would apply to all cases. Customers should consult with London Hydro in the early planning stages and submit the following information.

- a) Required in-service date.
- b) Voltage requirements.
- c) Estimated initial maximum electric demand.
- d) Estimated future maximum electric demand.
- e) Plan to install a distributed energy resource (DER) such as solar, battery storage or combined heat and power generation.
- f) Specific listing of the type of loads for lighting, motors, heating, air conditioning, or other.
- g) Grading plan and site plan, to scale, showing the building or buildings in relation to existing or proposed property lines, and other buildings or structures such as parking garages and loading ramps. If applicable, the plans should include vertical and horizontal views of the proposed incoming duct bank from the point of entry to the delivery point.
- h) Number of suites and/or divisions within the building(s) and the areas of each.
- i) Plan, to scale, of the area in which the transformer vault is to be located (if one is required), showing detail of the vault.
- j) Plan, to scale, showing the electrical room and provision for the metering equipment.
- k) A drawing if applicable depicting the single line riser schematic for the entire primary/secondary distribution system.
- l) Where drawings are required by London Hydro, the Customer/Consultant will be required to provide digital format drawings. Digital drawings shall be supplied as georeferenced AutoCad files (.dwg format) or Microstation (*.dgn format). Information can be emailed or compressed into a ZIP file onto one or more disc volumes as required. The contents of the drawing files must explicitly follow layering, colour, and line-type schemes as set out by the City of London's GIS specifications.

3.2.2 Point of Demarcation

For the purpose of this section, the points of demarcation described below refer to both the ownership and maintenance (operational) demarcation point. The point of demarcation for various service types is generally as follows:

3.2.2.1 Overhead Secondary Services

For overhead secondary services, the point of demarcation is at the connection point where London Hydro's service drop connects to the Customer's anchor point and service mast weatherhead. London Hydro is responsible for the maintenance and repair of the transformer, transformer hardware, and the first 30m of the overhead service wire. The Customer is responsible for the maintenance and repair of the anchor point,

weatherhead and all points downstream of the connection splice including the meter socket base and the jaw and connection block assemblies. London Hydro is responsible for the maintenance and repair of the electric meter.

3.2.2.2 Underground Secondary Services

For underground secondary services fed from padmount transformers, where the number of secondary conductors does not exceed 16 (4 per phase) plus neutral or where the conductors are not larger than 750 kcmil, the point of demarcation is at the secondary terminals of the transformer. If the Customer requires the use of a larger conductor size or more conductors per phase please contact the Engineering Design department to discuss further options. The Customer is responsible to maintain and repair the secondary cable terminators, secondary cables and all equipment downstream with the exception of any metering CTs and PTs and London Hydro's associated metering equipment. London Hydro is responsible for maintaining and repairing the electric meter, the padmount transformer and all primary cables and equipment upstream of the point of demarcation.

For installations with many parallel conductors or large cable sizes, London Hydro may supply and install a secondary distribution tap box and concrete foundation to relieve congestion inside the padmount transformer. The point of demarcation will be at the customer owned secondary terminals inside the tap box. The Customer is responsible to maintain and repair the secondary cable terminators, secondary cables and all equipment downstream with the exception of any metering CTs and PTs and London Hydro's associated metering equipment. London Hydro is responsible for maintaining and repairing the secondary distribution tap box, the electric meter, the padmount transformer, the secondary cables and terminations from the padmount transformer to the distribution tap box and all primary cables and equipment upstream of the point of demarcation.

For secondary connections in Customer vaults, the point of demarcation is at the secondary cable terminators. The Customer is responsible to maintain and repair the secondary cable and terminators and all equipment downstream with the exception of any metering CTs and PTs or metering equipment if it is located on the secondary side of the service. The Customer is also responsible for maintaining the structural integrity of the Customer owned vault and keeping it in a dry, non-humid and safe environment. Repairs must be made by a "competent" person as defined in the Occupational Health and Safety Act. London Hydro is responsible for maintaining the transformers and any primary cables and equipment upstream of the point of demarcation. London Hydro is also responsible for the metering CTs & PTs and any associated equipment.

For secondary services fed from the downtown network system, the point of demarcation is at the secondary cable connections at the Customer's service entrance equipment or at the Customer-owned bus duct. The Customer is responsible for the maintenance of the service entrance equipment or the bus duct and all points downstream with the exception of any metering CTs and PTs and associated metering equipment. London Hydro is responsible for the maintenance and repair of the secondary cables upstream of the point of demarcation as well as the maintenance of any transformers and vaults located in the City of London right-of-way. In cases where the vault is supplied by the Customer because of lack of space in the right of way, the Customer is responsible for maintaining the structural integrity of the vault and keeping it in a dry, non-humid and safe condition.

3.2.2.3 Service Lengths Greater than 100 metres

For Customers whose service entrance is located more than 100 metres from the right-of-way, a high voltage primary line (either overhead or underground) will be required. The Customer can choose to own and maintain the primary portion of the line or they elect to pay London Hydro to install the primary line in an agreeable location. In this case, London Hydro will own and maintain the line. If the Customer is responsible

to maintain the primary line, the point of demarcation for overhead lines is at the first pole and the point of demarcation for underground lines is at the primary cable riser connection. The Customer is responsible for the maintenance and repair of all poles, primary and secondary conductors and hardware, (including regular tree trimming), primary cable terminators, cable hangers, and primary cables. London Hydro is responsible for the transformer and transformer hardware.

In all cases, if a Customer requires a primary line on their property, the Customer must sign a Connection Agreement that will describe in detail which party is responsible for the maintenance of various components of the line. The Agreement will also describe operational requirements necessary to provide isolation and protection of personnel and plant.

3.2.2.4 Customer-Owned Substations

For customer-owned substations, London Hydro supplies the Customer at high voltage and the Customer owns all high voltage equipment, transformers, and points downstream.

For overhead high voltage primary services, the point of demarcation is at the first pole or connection point on the Customer's property. The Customer is responsible for the maintenance and repair of all poles, primary conductors, disconnect switches, substation equipment and transformers downstream. London Hydro is responsible for the aerial primary conductor and any in-line disconnect switches or power fuses upstream of the first pole or connection point on the Customer's property.

For underground high voltage primary services, the point of demarcation is at the primary cable riser or padmounted switchgear connection. The Customer is responsible for the maintenance and repair of the primary cable terminators or elbows, primary cables, substation equipment and transformers downstream of the demarcation point with the exception of metering CTs and PTs and associated metering equipment. London Hydro is responsible for the cable riser fused disconnect switch, lightning arresters and hanging the Customer's terminated cable on the riser pole, or installation of the padmounted switchgear. The Customer is responsible for providing the supports for hanging the cable and the U-guard protection for the first 10 feet.

For underground high voltage primary services primary metered installed after April 2024, the demarcation point is on the load side of the primary metering unit. The Customer is responsible for the maintenance and repair of the primary cable elbows, primary cables, substation equipment and transformers downstream of the demarcation point. London Hydro is responsible for the cable riser fused disconnect switch, lightning arresters, primary cable terminations, primary cables upstream of the demarcation point, primary metering enclosure, metering CTs and PTs, and associated metering equipment.

Customers have an obligation to maintain their customer-owned equipment on a regular basis. London Hydro reserves the right to disconnect customer-owned equipment if they believe it poses a safety or system reliability risk.

3.2.2.5 Deviations

In cases where there is a deviation in demarcation from what is described above, a separate Connection Agreement must be signed by the Customer and London Hydro to define each party's responsibilities. The Agreement will also describe operational requirements necessary to provide isolation and protection of personnel and plant.

3.2.3 Supply of Transformation and Fuse Coordination

The electric servicing of most commercial, industrial, institutional, and apartment buildings is via transformation supplied, owned, operated, and maintained by London Hydro.

However, there are a number of circumstances when a Customer must supply, own, operate and maintain their own electric power substation. These circumstances are described in detail in Appendix C "Design and Interconnection Requirements for Customer-Owned Electric Power Substations", Section 1.4.

It is London Hydro's practice to provide transformation to supply the Customer's actual demand. As such, the main switch and/or breaker setting may need to be fused or set at a lower level to provide coordination with London Hydro's primary transformer fuse. London Hydro will provide the time - current characteristic curve of the upstream protection to the Customer's Consultant. The onus is on the Customer to confirm suitable coordination.

3.2.4 Short Circuit Capacity

The Customer must ensure that their service entrance equipment has an adequate circuit interrupting capability in order to demonstrate compliance with Rule 14-012, Types and Ratings of Protective and Control Devices, of the Ontario Electrical Safety Code. London Hydro will provide on request, the maximum short circuit current available at any specific location and will provide short circuit information at either the primary point of supply if the service is a Customer-owned substation or at the secondary bushings at the transformer supplied by London Hydro. Maximum short circuit levels are provided since the actual levels may change from time to time as London Hydro's primary distribution circuits are reconfigured, capacity at supply transformer stations is increased, generation facilities are connected, or as Hydro One's transmission/generation systems are modified.

3.2.5 Access and Easements

The Customer shall grant, at no cost to London Hydro, where requested, an easement to permit the installation and maintenance of service. See Section 2.1.6.

3.2.6 Servicing Details

The following information applies to larger general service Customers:

3.2.6.1 Overhead Secondary Services

For information regarding the maximum size of overhead secondary services that can be installed for various voltages, contact New Services and Connections; refer to Section 1.5 for contact information.

Customers may be required to provide space for the transformer pole and transformer bank on their private property at the discretion of London Hydro.

Customers may at their option choose to provide their own underground secondary service cables to be fed from London Hydro's overhead transformer bank. This is described in the following section.

3.2.6.2 Underground Secondary Services

i) Supplied from London Hydro's Overhead System

The Customer may at their option provide underground secondary servicing from London Hydro's overhead system provided that:

- Service size is limited to 600 amperes, 120/208Y or 347/600Y volts.

In special circumstances, London Hydro may allow the connection of an 800 ampere 120/208Y volt service - special application must be made to London Hydro.

- Secondary conductors are subject to approval by the Electrical Safety Authority and are limited to the numbers and maximum sizes as follows:
- For Corflex conductors, a maximum of 1 run of four 750 kcmil aluminum/copper conductors.
- For copper conductors and conduit, 1 run of four 500 kcmil copper conductors in one 4" rigid PVC conduit. The Customer must supply conduit, weatherhead(s) and all mounting hardware.
- A pole may be required on the Customer's property to terminate their underground service cables. The location of the pole must be approved by London Hydro and the installation must pass inspection by the Electrical Safety Authority.

ii) Supplied from a London Hydro Owned Padmount Transformer

London Hydro will supply, install and maintain padmount transformation on the Customer's property up to 2,000 KVA for a 347/600Y volt secondary service and up to 750 KVA for 120/208Y volt secondary services. London Hydro will supply and install the primary duct structure, cable, transformer foundation, ground grid, and the transformer, and will make the primary cable terminations as well as the secondary cable terminations at the padmount transformer. London Hydro will supply the secondary conductor termination connectors at the padmount transformer. For underground secondary services where the number of secondary conductors exceeds 16 (4 per phase plus neutral) or where the conductors are larger than 750 kcmil, installation of a secondary distribution tap box and concrete foundation is required to relieve congestion inside the padmount transformer. The tap box and foundation can be supplied and installed either by London Hydro at the customer's cost or by the customer. London Hydro will provide the customer with the specifications for the tap box and although it must be purchased and installed by the customer, once it is installed, London Hydro will assume ownership of the tap box and will be responsible to maintain and repair it.

The Customer must provide the following:

- An accessible and safe location satisfactory to London Hydro and the Electrical Safety Authority for installing and maintaining the transformer installation and secondary distribution tap box if required. (See Ontario Electrical Safety Code Section 26-014 - Dielectric Liquid-Filled Equipment Outdoors). London Hydro may require the installation of traffic bollards at the transformer location.
- An accessible route for London Hydro's primary cable trench to allow for the installation of duct structure and to allow for pulling points if required (concrete pull boxes and/or precast manholes). Under no circumstances will the primary duct structure be permitted to exist under a building's foundation.

iii) The Customer is responsible for the supply and installation of all secondary conductors from their service entrance to London Hydro's padmount transformer or to the secondary distribution tap box in accordance with Electrical Safety Authority approval. London Hydro will allow up to 16 individual cables per transformer (4 cables per phase) with a maximum conductor size of 750 kcmil copper or aluminum. For services where the number of secondary conductors exceeds 16 (4 per phase plus neutral) or where the conductors are larger than 750 kcmil, a secondary distribution tap box and concrete foundation will be required. Dual Transformers

London Hydro will permit a Customer to install double-ended low voltage switchgear complete with a tie breaker for larger 347/600Y volt services up to a maximum of 1600 amperes. This will allow London Hydro

to install 2 padmount transformers to service an individual installation. In the event of single transformer failure, the remaining transformer can carry as much as 153% of its nameplate rating (depending on the previous duty cycle and ambient temperature) for up to 4 hours (the time usually required for London Hydro to change out a failed transformer). This type of installation can provide the Customer with added security, although in some case the Customer may be required to shed non-critical loads depending on when the failure occurs.

See Section 2.1.8 for additional discussion on Dual Supply and Backup Feeds.

3.2.7 Metering

Please refer to Appendix B "Low Voltage Electric Metering Requirements" for details on London Hydro's metering requirements.

3.3 General Service (Above 50 kW)

In addition to the requirements of Sections 3.2, London Hydro requires interval metering on all new services having a monthly average peak demand during the calendar year of over 50 kW. Please refer to Appendix D "Guidelines for Supplying Interval-Style Revenue Metering Systems".

3.4 General Service (Above 1000 kW)

Please see section 3.3 above.

3.5 Embedded Generation

Note: Certain areas in London Hydro's service territory are capacity constrained as it relates to their ability to accept generation. Before considering any embedded generation project, please complete the Initial Feasibility Assessment form located on London Hydro's website or contact generation@londonhydro.com or by phone at 519-661-5800 ext. 5723.

3.5.1 General Requirements

All Embedded Generators must execute a Connection Agreement. The connection and operation of a Customer's embedded generator must not endanger workers or jeopardize public safety, or adversely affect or compromise equipment owned or operated by London Hydro, or affect the security, reliability, efficiency or the quality of electrical supply to other Customers connected to London Hydro's distribution system. If damage or increased operating costs result from a connection with a generator, London Hydro shall be reimbursed for these costs by the generator. The Embedded Generator shall be responsible for all costs associated with London Hydro performing studies and developing plans for risk mitigation that are to the satisfaction of London Hydro. Please refer to the London Hydro website for information regarding the general application process for connection of embedded generation (www.londonhydro.com).

3.5.1.1 Interface Protection and Isolating Devices

The Embedded Generator shall provide an interface protection scheme that minimizes the frequency and severity of disturbances on the distribution system and the impact on other customers. The Embedded Generation facilities must also meet the technical requirements as identified in the Connection Agreement. The interface protection shall be capable of automatically isolating the Generator (s) from the distribution system in the following situations:

- (a) internal faults within the Generation facility
- (b) external faults in the distribution system; and
- (c) abnormal system conditions, including, but not limited to open phase and islanding, over/under voltage and over/under frequency.

The Embedded Generator shall provide, install and maintain a disconnecting device at the connection point with the distribution system for the purpose of isolating the Embedded Generation facility in case of emergency and for work protection. The disconnecting device shall:

- (a) be located at or near to the demarcation point of connection of the Embedded Generation facility to the distribution system (for residential customers, within 1 meter of the service entrance point or electric meter), and must be readily accessible;
- (b) provide a visible indication of the open main current-carrying path that isolates the Embedded Generation facility from the distribution system;
- (c) have a three-pole gang operated switch mechanism suitable for load break operations at rated load. (Subject to London Hydro's prior written approval, single phase customers may use single pole switches or openers);
- (d) meet Ontario Electrical Safety Code requirements, (i.e. shall have a valid certification mark indicating it is approved for use in Canada);
- (e) be rated for maximum fault current available at that location on the distribution system; and
- (f) be lockable in the open position, (the lock will be provided by London Hydro and must be operated by London Hydro only).

3.5.1.2 Compliance

All equipment of Embedded Generators connected, operating or procured before May, 2002 is deemed to be in compliance with London Hydro's performance requirements except for the requirements of the Electrical Safety Authority and isolating device requirements identified in Section 3.5.1.1.

London Hydro may require the equipment deemed compliant above be brought into actual compliance with London Hydro's performance requirements within a timeframe established by London Hydro, but not to exceed 12 months, where, at London Hydro's sole opinion, there is:

- (a) a material deterioration of the distribution system reliability resulting from the performance of the Embedded Generator's equipment; or
- (b) a material negative impact on the power quality of an existing or new customer resulting from the performance of the equipment at the Embedded Generation facility; or
- (c) a material increase in Generating capacity at the site where the equipment deemed compliant is located.

3.5.2 Micro Generation General Requirements (<10kW)

3.5.2.1 Documentation

All Embedded Generators shall provide London Hydro with the following documentation to ensure that the Distribution System is adequately protected from potential damage or increased operating costs resulting from the connection of the Embedded Generation Facility:

- (a) evidence of approval of the Electrical Safety Authority for all the Embedded Generator's owned electrical facilities.
- (b) any other documentation reasonably related to London Hydro's obligations.

3.5.2.2 Disconnection of Embedded Generation Facility

London Hydro has the right to disconnect an Embedded Generation facility from its distribution system where, in the sole opinion of London Hydro, any of the following conditions exist:

- (a) there is a material deterioration of the distribution system reliability resulting from the performance of the Embedded Generator's equipment;
- (b) there is a material negative impact on the quality of power of an existing or a new Customer resulting from the performance of the equipment at the Embedded Generation facility;

3.5.3 General Technical Information Requirements (>10kW)

3.5.3.1 Documentation

- a) electrical submissions signed and stamped by a licenced professional engineer; detailed single line diagrams showing all electrical devices associated with the Embedded Generation Facility such as generators, isolating devices, breakers, protection relays, inverter systems, instrument transformers, lightning arresters, fuses and metering.
- b) evidence of approval of the Electrical Safety Authority for all the Embedded Generator's owned electrical facilities.
- c) a copy of the report of the most recent re-verification of protections signed and stamped by a licenced professional engineer
- d) A Letter of Equivalency – Confirmation of Verification Evidence Report, stamped and signed by a Professional Engineer registered in Ontario, shall be provided before a Letter of Completion is issued by London Hydro. The form can be obtained on the London Hydro web site, and
- e) any other documentation reasonably related to London Hydro's obligations.

3.5.3.2 Metering for Embedded Generation Facilities

This section only applies to embedded generation facilities installed in larger commercial/industrial facilities with service sizes over 200 Amp. For smaller generators, please contact the Generation Dept. at 519-661-5800 Ext 5723. Also see Appendix B for metering details.

Metering Installations - Installed After May, 2002

The metering shall be installed at the demarcation point of connection of the Embedded Generation facility to the distribution system. If this is not practical, London Hydro will, where appropriate, apply loss factors to the generation output in accordance with the loss factors applied for Retail settlements and billing.

The Embedded Generator shall install a Four-Quadrant Interval Meter in accordance with the Distribution System Code and London Hydro's standard metering requirements. The Embedded Generator shall provide London Hydro with the technical details of the meter installation.

Embedded Generation Facilities That Do Not Deliver Power to the Distribution System

Behind the meter generation, that does not deliver power to the distribution system, requires an appropriate meter to be installed on the output of the generator. This is often achieved by the customer engaging a metering service provider (MSP) and enabling London Hydro to read the meter.

Notwithstanding the foregoing, the Embedded Generator shall pay all incremental costs associated with such metering.

Metering Installations - Installed Prior to May, 2002

Where there is an existing meter installation for an Embedded Generation facility, the Embedded Generator shall take ownership of the meter installation in accordance with London Hydro's requirements by no later than the meter seal expiry date. The Embedded Generator shall provide London Hydro with the technical details of the metering installations for review, if requested.

Embedded Generation facilities that receive energy e.g. for station use or back-up supply, shall be placed in the appropriate Rate class and billed for the energy consumed.

3.5.3.3 Transformers

Any step-up transformation equipment required to step-up the Embedded Generation facility's output voltage to a London Hydro standard secondary voltage shall be supplied, installed, owned and maintained by the Embedded Generator.

For customers connected to the distribution system that wish to install an Embedded Generation facility, London Hydro may, at its sole discretion, permit the Embedded Generation facility to be connected through London Hydro's existing transformer. In such cases, the Embedded Generator shall be responsible for any and all damage to London Hydro's facilities and equipment caused by the operation of the Embedded Generation facility.

3.5.3.4 Maintenance Schedules

The Embedded Generator must implement and adhere to a regular scheduled maintenance plan to assure both London Hydro and the Embedded Generator that the connection devices, protection and control systems are maintained in good working order. The provisions of the maintenance plan are to be listed in the Connection Agreement. The Embedded Generator must conduct a re-verification at least every 48 months (or as specified in the Connection Agreement) and provide a written report to London Hydro signed by a professional licenced engineer.

London Hydro in its sole discretion, may request to witness the re-verification of any protections that could adversely impact the distribution system. The Embedded Generator shall pay for the re-verification and provide London Hydro a copy of the report giving the results of the re-verification of the protections.

3.5.3.5 Reporting Requirements

All Embedded Generators over 100 kW shall report any significant event to London Hydro within 5 business days. The Connection Agreement may include a list of events deemed significant and provide a standard report format.

The Embedded Generator shall keep a written log of the operation of its protections that result in the tripping of its interrupting devices. On request, the Embedded Generator must provide a copy of the log to London Hydro. The log shall contain, at a minimum, the following information:

- (a) date and time of event/operation of protections
- (b) which relay or protection feature of the relay initiating the trip
- (c) conditions and unit output at the time of the trip that may be related to the operation (e.g. Lightning, outage of feeder, etc.).

3.5.3.6 Capital Contribution

When London Hydro is required to add new London Hydro facilities and equipment, alter existing London Hydro facilities and equipment, or increase the capacity of the distribution system to connect a new Embedded Generation facility (an "Expansion"), London Hydro will perform an economic evaluation to determine the Embedded Generator's capital contribution for the equipment, labour and ongoing maintenance costs of the Expansion as described in the Ontario Distribution System Code (DSC).

3.5.3.7 Disconnection of Embedded Generation Facility

London Hydro has the right to disconnect an Embedded Generation facility from its distribution system where, where in the sole opinion of London Hydro, any of the following conditions exist:

- (c) there is a material deterioration of the distribution system reliability resulting from the performance of the Embedded Generator's equipment;
- (d) there is a material negative impact on the quality of power of an existing or a new Customer resulting from the performance of the equipment at the Embedded Generation facility;
- (e) the Embedded Generator has failed to re-verify the protection and control systems every 48 months or as specified in the Connection Agreement or failed to submit the report within 30 days; or
- (f) the Embedded Generator's report of the re-verification of the protection and control systems shows unacceptable deficiencies.

3.6 Embedded Market Participant

Under the "Market Rules for the Ontario Electricity Market", Chapter 2, Section 1.2.1, "No persons shall participate in the IESO - administered Markets or cause or permit electricity to be conveyed into, through or out of the IESO - controlled grid unless that person has been authorized by the IESO to do so".

According to the Distribution System Code Section 6.1.4 "*A distributor shall enter into a Connection Agreement with a customer that is connected to the distributor's distribution system and is a wholesale market participant.*"

“Wholesale Market Participant”, means a person that sells or purchases electricity or ancillary services through the IESO-administered markets.

All Embedded Market Participants within the service jurisdiction of London Hydro, once approved by the IESO, are required to inform London Hydro of their approved status in writing, 30 days prior to their participation in the Ontario Electricity Market.

Pursuant to the OEB’s *Distribution System Code*, the Owner shall provide a communication option to the remote metering cabinet in accordance with the requirements set forth in London Hydro’s Engineering Instruction EI-22, *Guidelines for Supplying Interval-Style Revenue Metering Systems* as found in Appendix D.

The Customer is responsible to maintain and repair any equipment downstream including, but not limited to, any metering CTs and PTs, the Measurement Canada and/or IESO compliant electric meter and any other metering equipment. London Hydro is responsible for maintaining and repairing all equipment upstream of the point of demarcation.

Prior to adding any new or additional Embedded Generation, Embedded Wholesale Market Participants must execute a Generation Connection Agreement and be granted an offer to connect by London Hydro.

3.7 Embedded Distributor

All Embedded Distributors within the service jurisdiction of London Hydro are required to inform London Hydro of their status in writing 30 days prior to the supply of energy from London Hydro. The terms and conditions applicable to the connection of an Embedded Distributor shall be included in a Connection Agreement with London Hydro.

3.8 Unmetered Connections

This section pertains to the conditions of service and supply of electrical energy for unmetered connections.

All un-metered loads must be connected to a known fixed loads or defined duty cycles. Un-metered sporadic, event, or weather driven loads must be metered. Historically this has included cable TV power packs, bus shelters, telephone booths, traffic lights, and railway crossings.

The level of the consumption will be agreed to by the distributor and the customer, based on detailed manufacturer information/documentation with regard to electrical consumption of the unmetered load or periodic monitoring of actual consumption.

The customer must notify London Hydro of any changes to load impacting operations or demand/consumption characteristics.

London Hydro reserves the ability to require metering on already established un-metered loads. London Hydro reserves the ability to group unmetered services for the same customer onto one bill or with bills for metered services.

3.8.1 Street Lighting

The location of supply for street lighting circuits will vary and must be established through consultation with London Hydro for each application. Underground feeds will generally be supplied from padmount transformers, network vaults, or from an overhead system through a cable riser. Overhead systems will

normally be fed by way of individual connections for each street light from the secondary spun bus, or from a separate City of London owned street lighting circuit.

All underground cable feeds must be enclosed in separate conduit from the power source to the first pull box or disconnect switch. All underground street lighting services will require a separate disconnect switch to allow for isolation of the service without requiring the presence of London Hydro personnel. The overhead street lighting systems will not require disconnect switches unless the system is supplied from a separate City of London owned street lighting circuit.

The service voltage for overhead street lighting connections will be 120 volts, single phase, 2 wire and the service voltage for underground street lighting feeds will be 120 volts, single phase, 3 wire. The onus is on the installer to ensure a balanced loading between the two 120 volt legs of the supply.

Prior to the energization of a new street lighting service, London Hydro will require notification from the Electrical Safety Authority that the installation has been inspected and approved. The final power source connection will be made by London Hydro.

All street lighting services will be unmetered and energy consumption will be based on the connected wattage and the calculated hours of use using the approved methods and rates established by the OEB. A connection fee will apply in accordance with the applicable connection charges. For the applicable fee, contact New Services and Connections; refer to Section 1.5 for contact information. London Hydro personnel must be involved in the disconnection and reconnection of existing street light services fed from padmount transformers or vaults where there is no disconnect switch accessible to the City of London's street light contractor. A charge per trip will apply in accordance with the applicable charges.

3.8.2 Traffic Signals

The location of supply for traffic signal systems will vary and must be established for each application through consultation with London Hydro.

Feeds may be from either the overhead or underground electrical systems and in all cases a disconnect switch will need to be installed and approved by the Electrical Safety Authority. All cabling used for the purpose of traffic signal installations, must be installed in dedicated conduits separate from street lighting or any other secondary duct work.

The service voltage for traffic signal systems will be 120 volts, single phase, 2 wire.

Prior to the energization of a new traffic signal service, London Hydro will require notification from the Electrical Safety Authority that the installation has been inspected and approved. The final power source connection will be made by London Hydro.

London Hydro classifies traffic light intersections into configuration groups. Any time an intersection is modified (i.e. adds, removes or modifies the number of fixtures in an intersection, how they operate or the applicable wattage of the fixtures) London Hydro shall be notified of these changes within 30 days of the configuration change.

All traffic signal services will be unmetered and energy consumption will be based on the connected wattage and the quantity of devices used in the installation using the approved methods and rates established by the OEB. A connection fee will apply in accordance with the applicable connection charges. For the applicable fee, contact New Services and Connections; refer to Section 1.5 for contact information. London Hydro personnel must be involved in the disconnection and reconnection of existing traffic signal services fed from

padmount transformers or vaults where there is no disconnect switch accessible to the City of London's traffic signal contractor. A charge for disconnection/reconnection will apply in accordance with the applicable charges.

3.8.3 Bus Shelters

The service location for bus shelters will vary and must be established for each application through consultation with London Hydro. The service voltage will be 120 volts, single phase, 2 wire and the method of supply could be from either overhead or underground circuits.

All underground feeds must be in separate conduit from the bus shelter to the power supply location. For feeds originating from London Hydro's overhead system, the underground conduit for the cable riser will generally extend from the bus shelter to the nearest power supply pole. However, the service location could vary and London Hydro must be consulted for each application.

Prior to the energization of a new bus shelter service, London Hydro will require notification from the Electrical Safety Authority that the installation has been inspected and approved. The final power source connection will be made by London Hydro.

Bus service shelters will be unmetered and energy consumption will be based on the connected wattage and the calculated hours of use using the methods and rates approved by the OEB. A connection fee will apply in accordance with the applicable connection charges. For the applicable fee, contact New Services and Connections; refer to Section 1.5 for contact information.

3.8.4 Other Small Services

Small power supplies, communication amplifiers, utility cathodic protection, railway crossings, and similar small customer loads are included in this section. The service voltage will be either 120 volts, single phase, 2 wire or 120/240V, single phase, 3 wire. Feeds may be from either the overhead or underground electrical systems and in all cases a disconnect switch will need to be installed and approved by the Electrical Safety Authority.

Prior to the energization of a new service, London Hydro will require notification from the Electrical Safety Authority that the installation has been inspected and approved. The final power source connection will be made by London Hydro.

These small services may be unmetered and energy consumption will be based on the connected wattage and the calculated hours of use using the methods and rates approved by the OEB. A connection fee will apply in accordance with the applicable connection charges. For the applicable fee, contact New Services and Connections; refer to Section 1.5 for contact information.

3.8.5 Updating Unmetered Load Data

It is the responsibility of the unmetered load customer to notify London Hydro of any change such as wattage or usage pattern (ie. calculated hours of daily use) that would impact the billing amounts so that adjustments can be made to the bill on a go forward basis. Information regarding changes to streetlighting should be emailed to backofficesupport@londonhydro.com. Information for all other unmetered loads should be emailed to engadmin@londonhydro.com. This information must be supplied by a qualified individual who understands the operation of the device.

The unmetered load customer or London Hydro can initiate an audit at regular intervals or as required to ensure accurate billing.

3.8.6 Notification of Material Changes Affecting Unmetered Load Customers

London Hydro will communicate with all affected unmetered load customers in the event there is a material change that impacts them. These changes could relate to items such as preparation of cost allocation studies, load profile studies or other rate-related items.

4 GLOSSARY OF TERMS

"Affiliate Relationships Code" means the code, approved by the Ontario Energy Board.

"Billing Demand" means the metered demand or connected load after necessary adjustments have been made for power factor, intermittent rating, transformer losses and minimum billing. This is assessed at the higher of 100% kW or 90% kVA demand.

"Building" means a building, portion of a building, structure, or facility.

"Coincident Peak Demand" means demand occurring in the same time interval as the system peak demand occurring at the transmission connection point or transformer station. **"Conditions of Service"** means a document developed by a Distributor in accordance with subsection 2.4 of the Distribution System Code that describes the operating practices and connection rules for Distributors.

"Connection" means the process of installing and activating connection assets in order to distribute electricity to a Customer.

"Connection Agreement" means an agreement entered into between the Distributor and a person connected to its distribution system that delineates the conditions of the connection and delivery of electricity to that connection.

"Connection Assets" means that portion of the distribution system used to connect the Customer to the existing main distribution system, and consists of the assets between the point of connection on a Distributor's main distribution system and the ownership demarcation point with that Customer.

"Connection Authorization" when concerning supply of electrical energy to an electrical installation from a supply authority, shall mean written permission by the Electrical Safety Authority to London Hydro or any other person or corporation, to supply electric energy to a particular electrical installation; or

when concerning supply of electric energy from one part of an electrical installation to another, or from a source of electric energy other than that of London Hydro, shall mean permission from the inspection department to a contractor to connect a particular electrical installation or part thereof to a source of electric energy.

"Consumer" means a person who uses electricity that the person did not generate.

"Consumer's Service" shall mean all that portion of the Consumer's installation from the service box or its equivalent up to and including the point at which London Hydro makes connection.

"Contract" shall mean a contract for the supply of electrical service or energy.

"Contractor" shall mean any person who as principal, servant, or agent, by himself or herself or by associates, employees, servants or agents performs or engages to perform either for his or her own use and benefit or for that of another and for or without remuneration or gain any work with respect to any electrical installation or any other work to which the Ontario Electrical Code applies.

"Customer" shall mean the person or persons contracting for the supply of electric service or energy from London Hydro, including person or persons who are currently attached to the distribution grid and in receipt of electricity through default pursuant to the deregulation of the electricity market in May 2002. Customer should also include developers of residential or commercial subdivisions.

"Customer in Arrears" shall mean a Customer who owes to London Hydro charges or accounts for power after the due date, including an unpaid security deposit or reconnection fee.

"Demand" means the instantaneous value of power consumption measured, usually expressed in kilowatts (kW).

"Demarcation Point or Point of Demarcation" means the physical location at which a Distributor's responsibility for operational control or ownership and maintenance of distribution equipment including connection assets ends at the Customer. The demarcation point for operational control may be different than the demarcation point for the ownership and maintenance of equipment.

"Developer" means a Person or Persons owning property for which new or modified electrical services are to be installed.

"Disconnection" means deactivation of connection assets that result in cessation of distribution services to a Customer.

"Distribution Loss Factor" means a factor or factors by which metered loads must be multiplied such that when summed equal the total measured load at the supply point(s) to the distribution system.

"Distribution Losses" means energy losses that result from the interaction of intrinsic characteristics of the distribution network such as electrical resistance with network voltages and current flows.

"Distribution Services" means services related to the distribution of electricity and the services the Board has required Distributors to carry out, for which a charge or rate has been approved by the OEB under Section 78 of the Ontario Energy Board Act.

"Distribution System Code" means the code approved by the Ontario Energy Board.

"Distributor" means a Person who owns or operates a Distribution System.

"Electrical Safety Authority" or ESA means the Person or body designated under the Electricity Act Regulations as the Electrical Safety Authority.

"Electric vehicle" means a vehicle that is powered, in whole or in part, by electricity stored in rechargeable batteries. **"Electric Vehicle Supply Equipment"** means electrical supply equipment that is dedicated to supplying a source of electricity for the sole purpose of charging electric vehicles.

"Electricity Act" means the Electricity Act 1998, SO 1998.

"Eligible Renewable Generation Customer" means a customer with renewable generation who meets all distribution and Provincial requirements. **"Embedded Distributor"** means a Distributor who is not a Wholesale Market Participant and that is provided electricity by a Host Distributor.

"Embedded Generator or Embedded Generation Facility" means a Generator whose generation facility is not directly connected to the IESO - Controlled Grid but instead is connected to a Distribution System.

"Embedded Retail Generator" means an Embedded Generator that settles through a Distributor's Retail Settlement System and is not a wholesale market participant.

"Embedded Wholesale Consumer" means a Consumer who is a Wholesale Market Participant whose facility is not directly connected to the IESO - Controlled Grid but is connected to a Distribution System.

"Embedded Wholesale Generator" means an Embedded Generator that is a Wholesale Market Participant.

"Energy Competition Act" means the Energy Competition Act, 1998, SO-1998.

"Energy Diversion" means the electricity consumption unaccounted for but that can be quantified through various measures upon review of the meter mechanism, such as unbilled meter readings, tap off load(s) before revenue meter or meter tampering.

"Enhancement" means a modification to an existing distribution system that is made for purposes of improving system operating characteristics such as reliability or power quality or for relieving system capacity constraints resulting, for example from general load growth.

"Expansion" means an addition to a distribution system in response to a request for additional Customer connections that otherwise could not be made: for example, by increasing the length of the distribution system.

"EUSR" is the Electrical Utility Safety Rules.

"Gross Energy" means the energy consumed on the clock hour derived as imported (Consumed) energy plus generation less exported (Received) energy. The received energy is defined as the energy exported to the distribution system.

"Gross Peak Demand" in the context of embedded generation billing is equal to Import energy *plus* generation energy *less* export energy.

"IESO" means the Independent Electricity System Operator of Ontario.

"IHSA" is the Infrastructure Health and Safety Association.

"IMO" means the Independent Electricity Market Operator (IESO) established under the Electricity Act.

"Inspector" shall mean any person duly appointed by the Electrical Safety Authority for the purpose of enforcing the Ontario Electrical Code.

"Load Factor" means the ratio of average demand for a designated time period (usually one month) to the maximum demand occurring in that period.

"Load Transfer" means a network supply point of one Distributor that is supplied through the distribution network of another Distributor and where this supply point is not considered a wholesale supply or bulk sale point.

"Load Transfer Customer" means a Customer that is provided distribution services through a load transfer.

"Market Rules" means the rules made under the Electricity Act.

"Maximum Demand" means the highest demand reached in calendar year.

"Measurement Canada" means the Special Operating Agency established by the Electricity And Gas Inspection Act, 1980-81-82-83, C.87.

"Meter Service Provider" means any entity that performs metering services on behalf of a Distributor.

"Meter Socket" means a mounting device for accommodating a socket type revenue meter.

"Multi-Family Residential Dwelling" means a dwelling zoned residential by the City of London, used for dwelling purposes, containing more than one single family dwelling unit that are either individually metered or are metered with a bulk-meter having a service entrance capacity greater than 200 amps.

"Non-regulated price (NRPP) customer" refers to all SSS or Retailer associated customers that are not eligible to participate in the RPP or have elected to opt of the RPP.

"OEB" is the Ontario Energy Board, the regulatory authority in Ontario responsible for electricity and gas.

"On-Peak Demand" means the highest demand reached during a billing period between the hours of 7:00 AM and 7:00 PM, Monday to Friday, excluding holidays.

"Ontario Energy Board Act" means the Ontario Energy Board Act, 1998, S.O. 1998, C.15.

"Overdue Accounts" means amounts which are overdue in respect to a Customer's account including any unpaid security deposit.

"Peak Demand" means the highest demand reached during a billing period. This may also be referred to as 'Anytime Demand' or 'Non-Coincident Demand'. **"Permit"** shall mean the official written permission of the Electrical Safety Authority, on a form provided for the purpose, authorizing work to be commenced on any electrical installation.

"Person" includes an individual, corporation, a sole proprietorship, partnership, unincorporated organization, unincorporated association, body corporate, and any other legal entity.

"Physical Distributor" with respect to a load transfer, means the Distributor that provides physical delivery of electricity to a load transfer Customer, but is not responsible for connecting and billing the load transfer Customer directly.

"Point of Demarcation" see Demarcation Point.

"Premise" or **"Premises"** means the location at which an electrical Service is provided that has a London Hydro account.

Regulated price plan (RPP) customer refers to Low volume and designated customers that meet participant criteria defined in the OEB SSSC and Ontario Legislation or Regulation.

"Retail" with respect to electricity means,

- a) to sell or offer to sell electricity to a Consumer
- b) to act as agent or broker for a retailer with respect to the sale or offer for sale of electricity, or
- c) to act or offer to act as an agent or broker for a Consumer with respect to the sale or offering for sale of electricity.

"Retail Settlement Code" means the code approved by the Ontario Energy Board.

"Retailer" means a person who retails electricity.

"Secondary Service" means any service which is supplied with a nominal voltage less than 750 volts.

"Service Agreement" means the agreement that sets out the relationship between a licenced retailer and a Distributor in accordance with the provisions of Chapter 12 of the Retail Settlement Code.

"Service Area" with respect to a Distributor, means the area in which the Distributor is authorized by its licence to distribute electricity.

"Single Family Residential Dwelling" shall be a dwelling zoned residential by the City of London, used for dwelling purposes, and having only one electric meter with a service entrance capacity of 200 amps or less.

"Standard Supply Service Code" means the code approved by the Ontario Energy Board.

"Supply Service" shall mean any one set of conductors run by London Hydro from its electrical system to a Consumer's service.

"Wholesale Market Participant" means a person that sells or purchases electricity or ancillary services through the IESO - administered markets.

"Wholesale Settlement Cost" means costs for both competitive and non-competitive electricity services billed to a Distributor by the IESO or a Host Distributor or provided by an Embedded Retail Generator or by a neighbouring Distributor.

"Wholesale Supplier" means a person who sells electricity or ancillary services through the IESO administered markets or directly to another person other than a Consumer.

APPENDICES

Appendix A - Disconnection & Reconnection of Residential Service Cables

Appendix B - Low Voltage Electric Metering Requirements

Appendix C - Design & Interconnection Requirements for Customer-Owned Electric Power Substations

Appendix D - Guidelines for Supplying Interval-Style Revenue Metering Systems

Appendix E - Approved Retail Rates

Appendix F - Distributor Specific Electric Vehicle Charging Connection Requirements

APPENDIX A

DISCONNECTION AND RECONNECTION OF RESIDENTIAL METERS AND SERVICE CABLES

APPENDIX B

LOW VOLTAGE ELECTRIC METERING REQUIREMENTS

APPENDIX C

DESIGN AND INTERCONNECTION REQUIREMENTS FOR CUSTOMER-OWNED ELECTRIC POWER SUBSTATIONS

APPENDIX D

GUIDELINES FOR SUPPLYING INTERVAL-STYLE REVENUE METERING SYSTEMS

APPENDIX E

APPROVED RETAIL RATES

APPENDIX F

DISTRIBUTOR SPECIFIC ELECTRIC VEHICLE CHARGING CONNECTION REQUIREMENTS